



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

September 18, 2008

**Re: Knox County
Wyandot Golf Course
Transient Noncommunity Water System
PWSID: 4237112**

Rich Hauger
Keen Well & Pump, Inc.
20279 Coshocton Road
Mt. Vernon, OH 43050

Dear Mr. Hauger:

On August 25, 2008, I conducted an evaluation survey of the public water system at the Wyandot Golf Course.

During the survey, it was discovered that Keen Well & Pump had installed a buried pressure tank near the well head. Keen Well & Pump, Inc. is in violation of Ohio Administrative Code 3745-91-02(A) entitled Application for approval of plans.

The rule is outlined below in pertinent part:

“(A) No person shall....make a substantial change in a public water system, until plans therefore have been approved by the director of environmental protection.... An application for.....substantial change in a public water system, as required by section 6109.07 of the Revised Code, shall be submitted to the district office and shall consist of all of the following:

- (1) Three copies of plan drawings as specified by rule 3745-91-03 of the Administrative Code (two copies if the facility will be owned by a public entity);
- (2) One copy of specifications as specified by rule 3745-91-04 of the Administrative Code;
- (3) One copy of a data sheet as specified by rule 3745-91-05 of the Administrative Code;
- (4) One copy of supporting information as specified by rule 3745-91-06 of the Administrative Code; and

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Rich Hauger
Keen Well & Pump, Inc.
Page -2-

- (5) A submittal letter as specified by rule 3745-91-07 of the Administrative Code."

To comply with this violation, remove the tank within 45 days of the date of this letter, or submit a schedule for removal of the tank within 45 days of the date of this letter. If Wyandot Golf Course still desires to install another pressure tank, please submit detail plans to this office as outlined above.

Let me know if you have any questions or issues regarding this public water system. My phone number is (614) 728-3871.

Sincerely,



Mark Boden
Environmental Specialist
Division of Drinking and Ground Waters
Central District Office

c: Knox County Health Department
Dave Evans, DDAGW/CO
CDO File
Mr. Steve Arter, Wyandot Golf Course