



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: Notice of Violation
Auglaize County
Wapakoneta/Lima South KOA
Ohio EPA Permit No. 2PR00256
NPDES Permit No. OH0141682

September 23, 2011

Mr. John Schuettler
DNJ Properties LLC
Wapakoneta/Lima South KOA
14719 Cemetery Road
Wapakoneta, Ohio 45895

Dear Mr. Schuettler:

We are in receipt of your self-monitoring reports covering the months of April through June 2011 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance are attached on a separate sheet.

We have received your email response dated July 10, 2011, for the above referenced violations and require no further information at this time.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements, including adequate laboratory controls, appropriate quality assurance procedures, and records retention, as specified in your Part III-General conditions of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. For more information about pollution prevention, including fact sheets or U. S. EPA's "*Facility Pollution Prevention Guide*" (EPA/600/R-92.008), please contact the Ohio EPA Pollution Prevention Section at (614)644-3469.

If there are any questions, please contact me at (419) 373 – 3022.

Sincerely,

Justin A. Williams
Division of Surface Water

/cs

Enclosure

pc w/Enclosure: NWDO – DSW-File



Get New Data

Violations for Wapakoneta / Lima South KCA - April - June 2011

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
2PR00256*BD	June 2011	001	31616	Fecal Coliform	30D Conc	1000	1119.9	6/1/2011
2PR00256*BD	June 2011	001	80082	CBOD 5 day	30D Conc	10.0	12.51	6/1/2011



100