Ohio | Environmental Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: Notice of Violation
Auglaize County
Wapakoneta WWTP
Ohio EPA Permit No. 2PD00019
NPDES Permit No. OH0027952

September 23, 2011

Mr. Robert Burns, Superintendent
Wapakoneta WWTP
P. O. Box 269
Wapakoneta, Ohio 45895

Dear Mr. Burns:

We are in receipt of your self-monitoring report covering the months of April through June 2011 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance are attached on a separate sheet.

Please inform this office in writing as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements, including adequate laboratory controls, appropriate quality assurance procedures, and records retention, as specified in your Part III-General conditions of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. For more information about pollution prevention, including fact sheets or U. S. EPA's *"Facility Pollution Prevention Guide"* (EPA/600/R-92.008), please contact the Ohio EPA Pollution Prevention Section at (614)644-3469.

Northwest District Office
347 North Dunbridge Road
Bowling Green, OH 43402-9398

419 | 352 8461
419 | 352 8468 (fax)
www.epa.ohio.gov

If there are any questions, please contact Mr. Justin Williams at (419) 373 – 3022.

Sincerely,

Elizabeth A. Wick, P.E.
District Engineer/Manager
Division of Surface Water

/cs

Enclosure

pc w/Enclosure: NWDO – DSW File

Get New Data

Violations for Wapakoneta WWTP - April - June 2011

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
2PD00019*MD	May 2011	001	00300	Dissolved Oxygen	1D Conc	6.0	4.3	5/26/2011
2PD00019*MD	May 2011	001	50092	Mercury, Total (Low Le	30D Qty	0.0000	.00002	5/1/2011
2PD00019*MD	April 2011	001	50092	Mercury, Total (Low Le	30D Qty	0.0000	.00002	4/1/2011