



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: Wyandot County
The Olen Corp (Upper Sandusky)
NPDES Permit

October 11, 2011

Mr. Kenneth Holland
The Olen Corporation
4755 South High Street
Columbus, Ohio 43207

Dear Mr. Holland:

This will acknowledge our September 30, 2011, compliance inspection at your Upper Sandusky facility. This facility is located on 6326 County Road 61, Upper Sandusky. This inspection was conducted as part of your facility's National Pollutant Discharge Elimination System (NPDES) permit No. 2IJ00067 (OH0058360).

At the time of the inspection, there was no discharge from Outfall 001. When a discharge occurs from the pond, it must be sampled in accordance with this NPDES permit. We also in the process of renewing your existing NPDES permit, which will expire on February 29, 2012.

Our review of your Discharge Monitoring Reports (1/1/2010 to 9/1/2011) for this facility indicated some effluent violations. Please refer to the enclosed violation table. A completed inspection report is included for your review. If you have any questions or comments, please call me at 419-373-3021.

Sincerely,

Jason Ko
Division of Surface Water

pc: DSW-NWDO-File





Get New Data

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
2IJ00067*FD	March 2010	001	00530	Total Suspended Solids	30D Conc	30	53.8	3/1/2010
2IJ00067*FD	March 2010	001	00530	Total Suspended Solids	30D Qty	170	542.681	3/1/2010
2IJ00067*FD	March 2010	001	00530	Total Suspended Solids	1D Conc	45	53.8	3/30/2010
2IJ00067*FD	March 2010	001	00530	Total Suspended Solids	1D Qty	255	542.681	3/30/2010
2IJ00067*FD	June 2010	001	00530	Total Suspended Solids	30D Qty	170	259.013	6/1/2010
2IJ00067*FD	June 2010	001	00530	Total Suspended Solids	1D Qty	255	259.013	6/29/2010
2IJ00067*FD	May 2011	001	00530	Total Suspended Solids	30D Qty	170	209.204	5/1/2011

