



State of Ohio Environmental Protection Agency

STREET ADDRESS:

**Central District Office**

MAILING ADDRESS:

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

P.O. Box 1049  
Columbus, OH 43216-1049

June 29, 2007

Re: Licking County  
Camp O'bannon  
Transient Non-Community  
PWS ID #4549412

Executive Director  
Camp O'bannon  
9688 Butler Road Ne  
Newark, OH 43055

**Subject: Notice of Violation - Failure to Sample Drinking Water as Required for Total Coliforms**

Your public water system is in violation of Rule 3745-81-21 of the Ohio Administrative Code for failure to comply with the coliform monitoring requirements:

<b>Monitoring Period:</b>	<b>April - June 2007</b>
<b>Required Coliform Sampling:</b>	<b>At least 5 samples in the month after a coliform-positive result.</b>
<b>Sample Results Submitted:</b>	<b>3</b>

**Actions required as a result of the above violation**

Step 1	<p>Within 30 days issue public notice of the violation in accordance with rule 3745-81-32 of the Ohio Administrative Code by the following methods</p> <ol style="list-style-type: none"> <li>1. continuous posting, mail, or other direct delivery; and</li> <li>2. if necessary, the system must also use any other method reasonably calculated to reach all persons</li> </ol> <p>The language in <i>italics</i> on the attached public notice is mandatory and must be included as written.</p>
--------	--


Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

Executive Director  
Camp O'bannon  
Page -2-

Step 2	Within ten (10) days of completing <b>Step 1</b> above, fill out the attached verification form and send along with a copy of the public notification issued to the District Office of the Ohio EPA.
--------	--

If you have any questions, please contact me at (614) 728-5034.

Sincerely,



Linda Olvera  
Environmental Specialist II  
Division of Drinking and Ground Waters

Enclosures

c: Toni Buchanan, DDAGW, CO  
Licking County Health Department  
TB/CDO File  
Camp O'bannon, Executive Director

LO/sj 4549412\_Monitoring(24)\_April - June 2007