


SIGNATURE RECEIVED
OHIO

State of Ohio Environmental Protection Agency

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.usP.O. Box 1049
Columbus, OH 43216-1049

August 28, 2007

**Re: Licking County
Camp O'Bannon
Transient Non-Community
PWS ID #4549412
CERTIFIED #91 7108 2133 3932 4450 9389**

Executive Director
Camp O'Bannon
9688 Butler Road NE
Newark, OH 43055

**Subject: Notice of Violation of Maximum Contaminant Level for Total Coliform Bacteria
(ACUTE & Failure to Monitor with four repeat samples)**

During July 2007, your public water system incurred an **acute** violation of rule 3745-81-14 (D) of the Ohio Administrative Code (OAC) and a **monitoring** violation of rule 3745-81-21 (B)(1) of the OAC for failure to collect four (4) repeat samples within the required time period. **As a result of this violation, you are required to issue a water use advisory. Water must first be boiled prior to being used for potable purposes or bottled water must be provided.**


Actions required as a result of the above violation.	
Step 1	<p>Within 24 hours, consult with Ohio EPA and issue the attached public notice in accordance with rule 3745-81-32 of the Ohio Administrative Code using the following method(s) to reach all persons served by the public water system:</p> <p>Posting in conspicuous locations (restrooms, drinking fountains, vending areas, restaurants, bulletin boards, etc.)</p> <p>The language in italics on the attached public notice is mandatory and must be included as written.</p>
Step 2	Immediately initiate an investigation to determine and eliminate the cause and extent of bacterial contamination.
Step 3	Fill out the attached verification form and send along with a copy of the public notification issued within 10 days to the District Office of the Ohio EPA.
Step 4	Lifting the Advisory - The public notice water use advisory shall remain in effect until you obtain one complete set of four (4) total coliform-negative (contain no coliforms) repeat samples. Clearly mark each repeat sample slip as "repeat sample". It is advisable to notify your customers when the problem is corrected.
Step 5	Because you are required to monitor with at least five (5) samples in the next month following any total coliform-positive result you must take at least five (5) total coliform samples in August 2007.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Executive Director
Camp O'Bannon
Page -2-

If you have any questions, please contact me at (614) 728-5034.

Sincerely,

A handwritten signature in black ink, appearing to read "Linda Olvera". The signature is stylized and cursive.

Linda Olvera
Environmental Specialist II
Division of Drinking and Ground Waters
Central District Office

Enclosures

c: Toni Buchanan, DDAGW/CO
Licking County Health Department
CDO File

LO/msm 4549412 NOV21 25or26 July 2007