

SIGNATURE RECEIVED

1/4/08



State of Ohio Environmental Protection Agency

STREET ADDRESS:Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215**Central District Office**TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us**MAILING ADDRESS:**P.O. Box 1049
Columbus, OH 43216-1049

December 28, 2007

**Re: Licking County
Star Petroleum-Hebron Starfire
Transient Non-Community
PWS ID #4552512
CERTIFIED MAIL # 91 7108 2133 3932 4450 6548**

Office Manager
Star Petroleum-Hebron Starfire
1225 Woodlawn Avenue
Cambridge, OH 43725

Subject: Notice of Violation of Maximum Contaminant Level for Total Coliform Bacteria (ACUTE & Failure to Monitor with four repeat samples)

During November 2007, your public water system incurred an **acute** violation of rule 3745-81-14 (D) of the Ohio Administrative Code (OAC) and a **monitoring** violation of rule 3745-81-21 (B)(1) of the OAC for failure to collect four (4) repeat samples within the required time period. **As a result of this violation, you are required to issue a water use advisory. Water must first be boiled prior to being used for potable purposes or bottled water must be provided.**

Actions required as a result of the above violation	
Step 1	Within 24 hours , consult with Ohio EPA and issue the attached public notice in accordance with rule 3745-81-32 of the Ohio Administrative Code using the following method(s) to reach all persons served by the public water system: The language in italics on the attached public notice is mandatory and must be included as written.
Step 2	Immediately initiate an investigation to determine and eliminate the cause and extent of bacterial contamination.
Step 3	Fill out the attached verification form and send along with a copy of the public notification issued within 10 days to the District Office of Ohio EPA.
Step 4	Lifting the Advisory - The public notice water use advisory shall remain in effect until you obtain one complete set of four (4) total coliform-negative (contain no coliforms) repeat samples. Clearly mark each repeat sample slip as "repeat sample". It is advisable to notify your customers when the problem is corrected.
Step 5	Because you are required to monitor with at least five (5) samples in the next month following any total coliform-positive result you must take at least five (5) total coliform samples in December 2007.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Office Manager
Star Petroleum-Hebron Starfire
Page -2-

If you have any questions, please contact me at (614) 728-3874.

Sincerely,



Raymond Shesky
Environmental Specialist II
Division of Drinking and Ground Waters
Central District Office

Enclosures

c: Licking County Health Department
Toni Buchanan, DDAGW/CO
CDO File