



State of Ohio Environmental Protection Agency

* 0 H 4 5 5 5 1 1 2 8 6 6 6 3 0 9 *

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

CERTIFIED MAIL # 91 7108 2133 3932 4449 4913

April 9, 2010

**Re: Licking County
MPW Industrial Services Bldg
Non Transient PWS
PWS ID: 4555112**

Adam Leith
Director of Facilities
MPW Industrial Services, Inc.
9711 Lancaster Road SE
Hebron, OH 43025-0000

Dear Mr. Leith:

This letter is notification that the MPW Industrial Services, Inc. public water system is in violation of the Ohio Administrative Code (OAC) 3745-81-81 for failure to submit corrosion control recommendations and detail plans for optimal corrosion control treatment by March 30, 2010. This was required as a result of a lead action level exceedance in 2009 as stated in our letter dated November 16, 2009.

As a result of our discussion on April 6, 2010 and of my evaluation of the water quality parameters collected in November 2009, two recommendations were discussed. You would prefer to tie into the Village of Hebron public water system. The second recommendation is to install an orthophosphate feed system on your existing system. We accept your recommendations but need verification of such as described below.

1. Detail plans for an orthophosphate feed system need to be prepared by a PE and submitted into our office by no later than April 30, 2010.
2. The orthophosphate system is required to be installed and operated by no later than July 1, 2010 unless your recommendation to tie into the Village of Hebron occurs before that time.
3. A letter detailing a tie into the Village of Hebron needs to be sent to my office. It needs to include a schedule of events and the date the tie-in will be completed. You indicated a letter will be provided by April 16, 2010.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Adam Leith
MPW Industrial Services, Inc.
Page -2-

In order to avoid any further violations, please comply with each of the items listed above. If you have any questions regarding this letter, I can be reached at 614/728-3864.

Sincerely,



Carolyn O'Neal
Environmental Specialist III
Division of Drinking and Ground Waters
Central District Office

c: Licking County Health Department
Joe Hickman, Operator of Record
Ray Shesky, DDAGW/CDO
Tiara Bryant, DDAGW/CDO, Violation Code 57
Carolyn O'Neal w/file copy