

SIGNATURE  
Ohio

State of Ohio Environmental Protection Agency

FILE COPY

Central District Office

STREET ADDRESS:

MAILING ADDRESS:

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.usP.O. Box 1049  
Columbus, OH 43216-1049

September 17, 2007

Re: Licking County  
National Trail Raceway Grandstand  
Transient Non-Community  
PWS ID #4561812  
CERTIFIED #91 7108 2133 3932 4450 9495Jim Layton  
National Trail Raceway Grandstand  
2650 National Road SW  
Hebron, OH 43025**Subject: Notice of Violation of Maximum Contaminant Level for Total Coliform Bacteria  
(ACUTE - E. coli positive and a Monthly)**Your public water system incurred an **acute** and **monthly** violation of rule 3745-81-14 of the Ohio Administrative Code (OAC) in July - September 2007.

An acute violation occurs when:

- A repeat sample is either fecal or E. coli-positive; or
- A repeat sample is total coliform-positive following a fecal or E. coli positive routine sample.

A monthly violation of rule 3745-81-14 occurs when more than one or greater than five percent of your samples within the month were total coliform-positive.

Actions required as a result of the above violation	
Step 1	<p><b>Within 24 hours</b>, consult with Ohio EPA and issue the attached public notice in accordance with rule 3745-81-32 of the Ohio Administrative Code using the following method(s) to reach all persons served by the public water system:</p> <p>Posting in conspicuous locations (restrooms, drinking fountains, vending areas, restaurants, bulletin boards, etc.)</p> <p>The language in italics on the attached public notice is mandatory and must be included as written.</p>
Step 2	Immediately initiate an investigation to determine and eliminate the cause and extent of bacterial contamination.
Step 3	Fill out the attached verification form and send along with a copy of the public notification issued within 10 days to the District Office of the Ohio EPA.


Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

Jim Layton  
National Trail Raceway Grandstand  
Page -2-

Step 4	Lifting the Advisory - The public notice water use advisory shall remain in effect until you obtain one complete set of four (4) total coliform-negative (contain no coliforms) repeat samples. Clearly mark each repeat sample slip as "repeat sample". It is advisable to notify your customers when the problem is corrected.
Step 5	Because you are required to monitor with at least five (5) samples in the next month following any total coliform-positive result you must take at least five (5) total coliform samples in October 2007.

If you have any questions, please contact me at (614) 728-5034.

Sincerely,



Scot Foltz  
Manager  
Division of Drinking and Ground Waters  
Central District Office

Enclosures

c: Toni Buchanan, DDAGW/CO  
Licking County Health Department  
CDO File  
National Trail Raceway Grandstand, Water Operator

LO/nsm 4561812 July-September 2007