



State of Ohio Environmental Protection Agency

## STREET ADDRESS:

**Central District Office**

## MAILING ADDRESS:

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

P.O. Box 1049  
Columbus, OH 43216-1049

May 1, 2007

**Re: Licking County  
New Hope Bible Church  
Transient Non-Community  
PWS ID #4564912  
CERTIFIED #7006 2760 0002 9658 0202**

New Hope Bible Church  
12999 Worthington Rd.  
Pataskala, OH 43062

**Subject: Notice of Violation of Maximum Contaminant Level for Total Coliform Bacteria  
(ACUTE & Failure to Monitor with four repeat samples)**

During January - March 2007, your public water system incurred an **acute** violation of rule 3745-81-14 (D) of the Ohio Administrative Code (OAC) and a **monitoring** violation of rule 3745-81-21 (B)(1) of the OAC for failure to collect four (4) repeat samples within the required time period. **As a result of this violation, you are required to issue a water use advisory. Water must first be boiled prior to being used for potable purposes or bottled water must be provided.**

Actions required as a result of the above violation	
Step 1	<p><b>Within 24 hours, consult with Ohio EPA and issue the attached public notice in accordance with rule 3745-81-32 of the Ohio Administrative Code using the following method(s) to reach all persons served by the public water system:</b></p> <p>Posting in conspicuous locations (restrooms, drinking fountains, vending areas, restaurants, bulletin boards, etc.)</p> <p>The language in italics on the attached public notice is mandatory and must be included as written.</p>
Step 2	Immediately initiate an investigation to determine and eliminate the cause and extent of bacterial contamination.
Step 3	Fill out the attached verification form and send along with a copy of the public notification issued within 10 days to the District Office of the Ohio EPA.
Step 4	Lifting the Advisory - The public notice water use advisory shall remain in effect until you obtain one complete set of four (4) total coliform-negative (contain no coliforms) repeat samples. Clearly mark each repeat sample slip as "repeat sample". It is advisable to notify your customers when the problem is corrected.
Step 5	Because you are required to monitor with at least five (5) samples in the next month following any total coliform-positive result you must take at least five (5) total coliform samples in April 2007.

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

New Hope Bible Church  
Page -2-

If you have any questions, please contact me at (614) 728-5034.

Sincerely,

A handwritten signature in cursive script, appearing to read "Linda C. Olvera".

Linda Olvera  
Environmental Specialist II  
Division of Drinking and Ground Waters  
Central District Office

Enclosures

c: Toni Buchanan, DDAGW/CO  
Licking County Health Department  
CDO File

LO/nsm 4564912 NOV21 25or26 Jan-Mar 20007