



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215TELE: (614) 726-3778 FAX: (614) 726-3898
www.epa.state.oh.usP.O. Box 1049
Columbus, OH 43216-1049

November 29, 2007

**Re: Licking County
Papa Boo's
Transient Non-Community
PWS ID #4531412**

Owner
Papa Boo's
1424 Tiki Lane
Lancaster, OH 43130

**Subject: Notice of Violation - Failure to Sample Drinking Water as Required
for Total Coliforms**

Your public water system is in violation of Rule 3745-81-21 of the Ohio Administrative Code for failure to comply with the coliform monitoring requirements:

Monitoring Period:	October 2007
Required Coliform Sampling:	At least 5 samples in the month after a coliform-positive result.
Sample Results Submitted:	NONE

Actions required as a result of the above violation


Step 1	<p>Within 30 days issue public notice of the violation in accordance with rule 3745-81-32 of the Ohio Administrative Code by the following methods</p> <ol style="list-style-type: none"> 1. continuous posting, mail, or other direct delivery; and 2. if necessary, the system must also use any other method reasonably calculated to reach all persons <p>The language in italic on the attached public notice is mandatory and must be included as written.</p>
Step 2	<p>Within ten (10) days of completing Step 1 above, fill out the attached verification form and send along with a copy of the public notification issued to the District Office of Ohio EPA.</p>

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korteski, Director

Owner
Papa Boo's
Page -2-

If you have any questions, please contact me at (614) 728-3874.

Sincerely,



Raymond Shesky
Environmental Specialist II
Division of Drinking and Ground Waters
Central District Office

Enclosures

c: Licking County Health Department
Toni Buchanan, DDAGW/CO
CDO File
Justin Gano, Papa Boo's/Aquanu Technologies

RS/ct 4531412 NOV23or24 October 2007