



State of Ohio Environmental Protection Agency

Central District Office**STREET ADDRESS:**Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us**MAILING ADDRESS:**P.O. Box 1049
Columbus, OH 43216-1049

February 24, 2009

**Re: Madison County
Madison County Engineers Office PWS
PWS ID #OH4946012**

Madison County Engineers Office PWS
P.O. Box 618
London, OH 43140

Subject: Notice of Violation - Failure to Sample Drinking Water as Required for Lead and Copper

Your public water system is in violation of Rule 3745-81-80 through 3745-81-89 of the Ohio Administrative Code for failure to comply with the lead and copper monitoring requirements:

Monitoring Period:	July 1 - December 31, 2009
Required Sampling:	5 samples for each lead and copper
Sample Results Submitted:	None


Actions required as a result of the above violation	
Step 1	Collect and analyze the required number of lead and copper tap samples during January 1 - June 30, 2009. Based upon the reported population, you are required to collect a minimum of 5 lead and copper samples. Report results on the enclosed forms 5105, 5106 and 5107 by July 10, 2009.
Step 2	<p>Within 30 days issue public notice of the violation in accordance with rule 3745-81-32 of the Ohio Administrative Code by the following methods</p> <ol style="list-style-type: none"> 1. continuous posting, mail, or other direct delivery; and 2. if necessary, the system must also use any other method reasonably calculated to reach all persons <p>The language in italic on the attached public notice is mandatory and must be included as written.</p>

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Madison County Public Water System
Page -2-

If you have any questions, please contact me at (614) 728-5033.

Sincerely,

A handwritten signature in black ink, appearing to read "Susan Hampton". The signature is fluid and cursive, with the first name "Susan" written in a larger, more prominent script than the last name "Hampton".

Susan Hampton
Environmental Specialist III
Division of Drinking and Ground Waters
Central District Office

Enclosures

c: Madison County Health Department
Toni Buchanan, DDAGW/CO
CDO File

SKH/ct 4946012 51 2nd08