



Environmental  
Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

FILE COPY



**NOTICE OF VIOLATION – ACTION REQUIRED**

October 31, 2011

Kevin Blankenship  
Marysville Jehovahs Witness  
32261 Cobb-Harriman Road  
Richwood, OH 43344

Union County  
Marysville Jehovahs Witness  
Non-Community, Transient PWS  
PWS ID: OH8037212

**Subject: Violation of Total Coliform Maximum Contaminant Level (MCL)  
During October 2011 (Monthly)**

Marysville Jehovahs Witness is in violation of the Maximum Contaminant Level (MCL) for Total Coliform established by Ohio Administrative Code (OAC), Rule 3745-81-14. Coliform are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful bacteria may be present.

**ACTION REQUIRED:**

- 1. Investigate and eliminate the cause of bacterial contamination.** Special purpose samples may be collected to investigate the source of contamination or to verify elimination of the problem (these samples cannot be collected to comply with monitoring or MCL requirements; label samples as "special purpose").
- 2. Notify the people served by this water system.** Within 30 days issue the enclosed public notice in accordance with OAC, Rule 3745-81-32 by the following method(s) to reach all persons served.
  - Posting in conspicuous locations, such as bulletin boards, restrooms, drinking fountains, vending areas;
  - Mail or other direct delivery to each customer;
  - Send to parents or guardians of children at schools or day care facilities E-mail, newsletters or newspaper;
  - Posted notices must remain in place for as long as the violation exists, but in no case for less than seven days (even if the violation is resolved). The language in italics on the enclosed public notice is mandatory and must be included, as written. Do not make changes to the public notice without consulting with Ohio EPA beforehand.
- 3. Complete the enclosed verification form within 10 days of issuing the Public Notice and mail it to Ohio EPA - CDO.** Include a copy of each notice distributed, published or posted.

Central District Office  
50 West Town Street, Suite 700  
P.O. Box 1049  
Columbus, OH 43216-1049


614 | 728 3778  
614 | 728 3898 (fax)  
www.epa.ohio.gov

Kevin Blankenship  
Marysville Jehovahs Witness  
Page -2-

**4. Monitor with at least five (5) routine samples** in the month following a routine total coliform-positive result in accordance with OAC, Rule 3745-81-21(B)(7).

If you have any questions, contact this office at 614-728-5033.

Sincerely,



Susan K. Schell  
Environmental Specialist III  
Division of Drinking and Ground Waters  
Central District Office

Enclosures: Tier 2 Public Notification  
Public Notice Instructions and Verification Form

c: Union County Health Department  
Information Management Section, DDAGW/CO  
District File Copy

SKS/ct 8037212(Type22)Oct2011