



State of Ohio Environm



## STREET ADDRESS:

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

## Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

## MAILING ADDRESS:

P.O. Box 1049  
Columbus, OH 43216-1049

February 26, 2007

Re: Madison County  
National Road Golf, Inc.  
Transient Non-Community  
PWS ID #4943612  
**CERTIFIED #7006 2760 00010 2070 7010**

Brent Wohrle  
National Road Golf, Inc.  
5135 US Rt. 40  
West Jefferson, OH 43162

**Subject: Notice of Violation of Maximum Contaminant Level for Total Coliform Bacteria (ACUTE & Failure to Monitor with four repeat samples)**

During January 2007, your public water system incurred an **acute** violation of rule 3745-81-14 (D) of the Ohio Administrative Code (OAC) and a **monitoring** violation of rule 3745-81-21 (B)(1) of the OAC for failure to collect four (4) repeat samples within the required time period. **As a result of this violation, you are required to issue a water use advisory. Water must first be boiled prior to being used for potable purposes or bottled water must be provided.**

Actions required as a result of the above violation	
Step 1	<p><b>Within 24 hours</b>, consult with Ohio EPA and issue the attached public notice in accordance rule 3745-81-32 of the Ohio Administrative Code using the following method(s) to reach all persons served by the public water system:</p> <p style="text-align: center;">Posting in conspicuous locations (restrooms, drinking fountains, vending areas, restaurants, bulletin boards, etc.)</p> <p>The language in italics on the attached public notice is mandatory and must be included as written.</p>
Step 2	Immediately initiate an investigation to determine and eliminate the cause and extent of bacterial contamination.
Step 3	Fill out the attached verification form and send along with a copy of the public notification issued within 10 days to the District Office of the Ohio EPA.
Step 4	Lifting the Advisory - The public notice water use advisory shall remain in effect until you obtain one complete set of four (4) total coliform-negative (contain no coliforms) repeat samples. Clearly mark each repeat sample slip as "repeat sample". It is advisable to notify your customers when the problem is corrected.
Step 5	Because you are required to monitor with at least five (5) samples in the next month following any total coliform-positive result you must take at least five (5) total coliform samples in February 2007.

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

Patricia Tonti  
National Road Golf, Inc.  
Page -2-

If you have any questions, please contact me at (614) 728-5033.

Sincerely,



Susan Hampton  
Environmental Specialist III  
Division of Drinking and Ground Waters  
Central District Office

Enclosures

c: Toni Buchanan, DDAGW, CO  
Madison County Health Department  
(CDO File)

SH/nsm 4943612 NOV21 25or26 Jan. 2007