SIGNATURE RECEIVED
8/27/08

OH5941412 APPLE PIE INN 8/25/2008

Ohio

State of Ohio Environmental Protection Agency

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

CERTIFIED MAIL # 91 7108 2133 3932 4450 3103

August 25, 2008

Re: Morrow County
Apple Pie Inn Public Water System
Transient Noncommunity Water System
PWS ID: OH5941412

Ms. Jane Cobern
7398 S.R. 42
Mt. Gilead, OH 43338

Re: Subject: Notice of Violation for Failure to Respond to a Significant Deficiency

Dear Ms. Cobern:

This letter is notification that the Apple Pie Inn has not complied with requirements issued during this Agency's last survey performed on May 22, 2008, in violation of rule 3745-81-60 of the Ohio Administrative Code. You were notified in correspondence dated May 28, 2008 to respond in writing no later than 45 days, with time frames for:

1) Installing a vented, screened well cap;
2) Installing an operable pressure gauge;
3) Sending a copy of your completed sample siting plan, and
4) Using only NSF/ANSI certified salt in your softener.

The water system must respond in writing within 15 days from the date of this letter with the required information. Failure to comply may result in further enforcement action. You may notify me in writing via email at mark.boden@epa.state.oh.us or use the fax number or address provided in the letterhead.

If you have any questions, please contact me at 614-728-3871.

Sincerely,

Mark Boden
Environmental Specialist
Division of Drinking and Ground Waters
Cental District Office

c: Morrow County Health Department
DDAGW/CO

MB/ct ApplepieInnRTC

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Printed on Recycled Paper

Ohio EPA is an Equal Opportunity Employer