




State of Ohio Envir



STREET ADDRESS:

Central

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-0110 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

| |
|----------------------------------------------|
| NOTICE OF VIOLATION - ACTION REQUIRED |
|----------------------------------------------|

August 3, 2010

**Re: Morrow County
Highland Pizza and Ice Cream PWS
Non-Community, Transient
PWS ID: OH5942612**

Ken Stuff
6530 State Route 229
Sparta, OH 43350

Subject: Failure to Sample Drinking Water for Total Coliforms as Required

Highland Pizza And Ice Cream PWS is in violation of Ohio Administrative Code (OAC), Rule 3745-81-21 for failure to comply with the total coliform monitoring.

| | |
|--------------------------------------|------------------------|
| Monitoring Period: | Second Quarter of 2010 |
| Required Coliform Monitoring: | 1 routine per Quarter |
| Sample Results Submitted: | Zero |

To ensure the safety of drinking water provided by your system monitoring for total coliforms is essential.

ACTION REQUIRED:

- 1. Notify the people served by this water system** using one or more of the methods and the timing as required by OAC, Rule 3745-81-32 to reach all persons served.

Timing: As soon as practical, but no later than 30 days after learning of the violation:

- Posting in conspicuous location, such as bulletin boards, restrooms, drinking fountains, vending areas;
- Mail or other direct delivery to each customer;
- Newsletters or newspaper;
- E-mail to employees or students;
- Send to parents or guardians of children at schools or day care facilities;
- Posted notices must remain in place as long as the violation or situation exists, but in no case less than seven days (even if the violation is resolved). The language in italics on the enclosed public notice is mandatory and must be included, as written. Do not make changes to the public notice without consulting with the Ohio EPA beforehand.

- 2. Complete the enclosed Verification Form within 10 days of issuing the Public Notice** and mail it to Ohio EPA - CDO. Include a copy of each notice distributed, published or posted.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director




Ken Stuff
Page -2-

If total coliform samples were collected as required, submit the results as soon as possible. The monitoring violation would be rescinded and a reporting violation given for late submittal of the results.

If you have any questions, contact this office at 614-728-3871.

Sincerely,



Mark Boden
Environmental Specialist II
Division of Drinking and Ground Waters
Central District Office

Enclosures: Tier 3 Public Notification
Public Notice Instructions & Verification Form

c: Morrow County Health Department
Information Management Section, DDAGW/CO
District File Copy

MB/ct 5942612(Type23)2Qtr2010