

SIGNATURE RECEIVED

2/5/09



OH5941912

TERRY GALBRAITH

2/2/2009



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

CERTIFIED MAIL # 91 71082 133 3932 4450 0584

February 2, 2009

Re: Morrow County

Northfield Medical Center
Transient Public Water System
PWS ID: 5942012
STU ID: 5961627

Grant Galbraith MD, Inc.
Transient Public Water System
PWS ID: 5941912
STU ID: 5961626

Ms. Terry Galbraith
6519 U.S. Route 42
Mt. Gilead, OH 43338

Dear Ms. Galbraith:

Subject: Notice of Violation for Failure to Respond to a Significant Deficiency

This letter is notification that Northfield Medical and Grant Galbraith MD, Inc. has not complied with requirements issued during this Agency's last survey performed on August 28, 2008, in violation of rule 3745-81-60 of the Ohio Administrative Code. You were notified in correspondence dated September 12, 2008 to respond in writing no later than 45 days, with time frames for completion of the following items:

REQUIREMENTS

1. Once you have picked out a lab, fill out the sample siting plans and maintain them on site. Send a copy of the first page of each one to this office.
2. Use salt in your softener that has been properly certified to ANSI/NSF standard 60. Your supplier should have this available. Look for the ANSI, NSF, UL, or Water Quality Association certification marks on the containers.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Ms. Terry Galbraith
Page -2-

3. Be sure to follow the sampling schedule for total coliform and nitrate. I recommend sending a copy to your lab also. Begin sampling immediately, following the sampling schedule for both facilities that has been mailed to you under separate cover.
4. Air gap the softener drain tube on both sides (Grant Galbraith MD, Inc. and Northfield Medical).

You must respond within 15 days of the date of this letter with the required information. Failure to comply may result in further enforcement action.

Let me know if you have any questions or issues regarding your public water system. My phone number is (614) 728-3871.

Sincerely,



Mark Boden
Environmental Specialist
Division of Drinking and Ground Waters
Central District Office

c: Morrow County Health Department
Dave Evans, DDAGW/CO
File