



State of Ohio Environmental



* 0 H 6 5 4 0 2 1 2 9 7 4 9 5 1 0 *

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

NOTICE OF VIOLATION - ACTION REQUIRED
--

August 9, 2010

Re: **Pickaway County**
CC And JS Inc. dba Joseppis Pizza PWS
Non-Community, Transient
PWS ID: OH6540212

Chuck Thompson
4764 W Broad Street
Columbus, OH 43228

Subject: Violation of Total Coliform Maximum Contaminant Level (MCL)
During Third Quarter of 2010 (Monthly)

Cc And Js Inc. dba Joseppis Pizza PWS is in violation of the Maximum Contaminant Level (MCL) for Total Coliform established by Ohio Administrative Code (OAC), Rule 3745-81-14. Coliform are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful bacteria may be present.

ACTION REQUIRED:

1. **Investigate and eliminate the cause of bacterial contamination.** Special purpose samples may be collected to investigate the source of contamination or to verify elimination of the problem (these samples cannot be collected to comply with monitoring or MCL requirements; label samples as "special purpose").
2. **Notify the people served by this water system.** Within 30 days issue the enclosed public notice in accordance with OAC, Rule 3745-81-32 by the following method(s) to reach all persons served.
 - Posting in conspicuous locations, such as bulletin boards, restrooms, drinking fountains, vending areas;
 - Mail or other direct delivery to each customer;
 - Send to parents or guardians of children at schools or day care facilities E-mail, newsletters or newspaper;
 - Posted notices must remain in place for as long as the violation exists, but in no case for less than seven days (even if the violation is resolved). The language in italics on the enclosed public notice is mandatory and must be included, as written. Do not make changes to the public notice without consulting with Ohio EPA beforehand.
3. **Complete the enclosed verification form within 10 days of issuing the Public Notice** and mail it to Ohio EPA - CDO. Include a copy of each notice distributed, published or posted.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korteski, Director



Chuck Thompson
Page -2-

4. **Monitor with at least five (5) routine samples** in the month following a routine total coliform-positive result in accordance with OAC, Rule 3745-81-21(B)(7).

If you have any questions, contact this office at 614-728-3874.

Sincerely,



Raymond Shesky
Environmental Specialist II
Division of Drinking and Ground Waters
Central District Office

Enclosures: Tier 2 Public Notification
Public Notice Instructions and Verification Form
Level 1 Assessment

c: Pickaway County Health Department
Information Management Section, DDAGW/CO
District File Copy

RS/ct 6540212(Type22)3rdQtr2010