Ohio Environmental Protection Agency
John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

OH8040121

JAN 2011

OHIO EPA

NOTICE OF VIOLATION – ACTION REQUIRED

January 28, 2011

RE: Union County
Big Darby Pizza And Deli PWS
Non-Community, Transient
PWS ID: OH8040112

Dan Block
Po Box 151
Marysville, OH 43040

Subject: Failure to Sample Drinking Water for Total Coliforms as Required

Big Darby Pizza And Deli PWS is in violation of Ohio Administrative Code (OAC), Rule 3745-81-21 for failure to comply with the total coliform monitoring.

Monitoring Period:	Fourth Quarter of 2010
Required Coliform Monitoring:	1 routine per QT
Sample Results Submitted:	Zero

To ensure the safety of drinking water provided by your system monitoring for total coliforms is essential.

ACTION REQUIRED:

1. **Notify the people served by this water system** using one or more of the methods and the timing as required by OAC, Rule 3745-81-32 to reach all persons served.

   Timing: As soon as practical, but no later than 30 days after learning of the violation:

   - Posting in conspicuous location, such as bulletin boards, restrooms, drinking fountains, vending areas;
   - Mail or other direct delivery to each customer;
   - Newsletters or newspaper;
   - E-mail to employees or students;
   - Send to parents or guardians of children at schools or day care facilities;
   - Posted notices must remain in place as long as the violation or situation exists, but in no case less than seven days (even if the violation is resolved). The language in italics on the enclosed public notice is mandatory and must be included, as written. Do not make changes to the public notice without consulting with the Ohio EPA beforehand.

2. **Complete the enclosed Verification Form within 10 days of issuing the Public Notice** and mail it to Ohio EPA - CDO. Include a copy of each notice distributed, published or posted.

If total coliform samples were collected as required, submit the results as soon as possible. The monitoring violation would be rescinded and a reporting violation given for late submittal of the results.

If you have any questions, contact DDAGW, Central District Office at (614) 728-3778.

Sincerely,

Susan Baughman
Env. Specialist, DDAGW, Central Office

Enclosures: Tier 3 Public Notification
Public Notice Instructions & Verification Form

cc: Union County Health Department
Information Management Section, DDAGW, CO
District Office File