



State of Ohio Env



\* 0 H 2 3 5 0 9 1 2 8 0 6 5 9 0 8 \*

Central District Office

STREET ADDRESS:

MAILING ADDRESS:

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

P.O. Box 1049  
Columbus, OH 43216-1049

October 23, 2007

Re: **Fairfield County**  
**Double J Market & Deli**  
**Transient Non-Community PWS**  
**PWS ID # 2350912** 712

Double J Market & Deli  
8595 Snortin Ridge Road  
Lancaster, OH 43130

**Subject: Notice of Violation of Maximum Contaminant Level for Total Coliform Bacteria (ACUTE & Failure to Monitor with four repeat samples)**

During October - December 2007, your public water system incurred an **acute** violation of rule 3745-81-14 (D) of the Ohio Administrative Code (OAC) and a **monitoring** violation of rule 3745-81-21 (B)(1) of the OAC for failure to collect four (4) repeat samples within the required time period.

Actions required as a result of the above violation	
Step 1	<p><b>Within 24 hours</b>, consult with Ohio EPA and issue the attached public notice in accordance with rule 3745-81-32 of the Ohio Administrative Code using the following method(s) to reach all persons served by the public water system:</p> <p>Posting in conspicuous locations (restrooms, drinking fountains, vending areas, restaurants, bulletin boards, etc.)</p> <p>The language in italics on the attached public notice is mandatory and must be included as written.</p>
Step 2	Immediately initiate an investigation to determine and eliminate the cause and extent of bacterial contamination.
Step 3	Fill out the attached verification form and send along with a copy of the public notification issued within 10 days to the District Office of Ohio EPA.

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

Double J Market & Deli  
Page -2-

Step 4	Lifting the Advisory - The public notice water use advisory shall remain in effect until you obtain one complete set of four (4) total coliform-negative (contain no coliforms) repeat samples. Clearly mark each repeat sample slip as "repeat sample". It is advisable to notify your customers when the problem is corrected.
--------	--

If you have any questions, please contact me at (614) 728-728-3866.

Sincerely,



Susan Applegate  
Environmental Specialist II  
Division of Drinking and Ground Waters  
Central District Office

Enclosures

c: Fairfield County Health Department  
Toni Buchanan, DDAGW/CO  
CDO File