

SIGN. JL

OH2339612 OLD TOWN TAVERN

25 09/28/07 1

10/11/07



St.

Central District Office

ING ADDRESS:

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

September 28, 2007

**Re: Fairfield County
Old Town Tavern
Transient Non-Community
PWS ID #2339612
CERTIFIED #91 7108 2133 3932 4450 9570**

Old Town Tavern
10985 Winchester Road NW
Canal Winchester, OH 43110

Subject: Notice of Violation of Maximum Contaminant Level for Total Coliform Bacteria (ACUTE, MONTHLY & Failure to Monitor with four repeat samples)

During September 2007, your public water system incurred **acute** and **monthly** violations of rule 3745-81-14 of the Ohio Administrative Code (OAC) and a **monitoring** violation of rule 3745-81-21 (B)(1) of the OAC.

Acute and monitoring violations occur when four (4) total coliform bacteria repeat samples are not collected as required. **As a result of this violation, you are required to issue a water use advisory. Water must first be boiled prior to being used for potable purposes or bottled water must be provided.**

A monthly violation occurs when more than one or greater than five percent of your samples within the month are total coliform-positive.


Actions required as a result of the above violation	
Step 1	<p>Within 24 hours, consult with Ohio EPA and issue the attached public notice in accordance rule with 3745-81-32 of the Ohio Administrative Code using the following method(s) to reach all persons served by the public water system:</p> <p>Posting in conspicuous locations (restrooms, drinking fountains, vending areas, restaurants, bulletin boards, etc.)</p> <p>The language in italics on the attached public notice is mandatory and must be included as written.</p>
Step 2	<p>Immediately initiate an investigation to determine and eliminate the cause and extent of bacterial contamination.</p>
Step 3	<p>Fill out the attached verification form and send along with a copy of the public notification issued within 10 days to the District Office of the Ohio EPA.</p>

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korteski, Director

Step 4	Lifting the Advisory - The public notice water use advisory shall remain in effect until you obtain one complete set of four (4) total coliform-negative (contain no coliforms) repeat samples. Clearly mark each repeat sample slip as "repeat sample". It is advisable to notify your customers when the problem is corrected.
Step 5	Because you are required to monitor with at least five (5) samples in the next month following any total coliform-positive result you must take at least five (5) total coliform samples in October 2007.

If you have any questions, please contact me at (614) 728-3871.

Sincerely,



Scot Foltz
Manager
Division of Drinking and Ground Waters
Central District Office

Enclosures

c: Toni Buchanan, DDAGW/CO
Fairfield County Health Department
CDO File