

SIGNATURE R  
Ohio

State of Ohio Environmental Protection Agency

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.usP.O. Box 1049  
Columbus, OH 43216-1049

September 20, 2007

Re: Franklin County  
Buckeye Landscape Services  
Non-Transient Non-Community  
PWS ID #2557712  
CERTIFIED #91 7108 2133 3932 4450 9518Fred Smith, Sumar Investment Co.  
Buckeye Landscape Services  
10 Newhall Road  
Hilton Head Island, SC 29928Subject: Notice of Violation of Monthly Maximum Contaminant Level  
for Total Coliform BacteriaYour public water system incurred a **monthly** violation of rule 3745-81-14 of the Ohio Administrative Code (OAC) in September 2007.

A monthly violation of rule 3745-81-14 occurs when more than one or greater than five percent of your samples within the month were total coliform-positive.

Actions required as a result of the above violation	
Step 1	<p>Immediately initiate an investigation to determine and eliminate the cause and extent of bacterial contamination. Each total coliform positive ROUTINE sample must be followed by four (4) repeat (<i>check</i>) samples. Repeat samples shall be collected within twenty-four (24) hours of being notified of the routine coliform positive result and shall not exceed 14 days from the positive routine sample collection date. Repeat samples shall be collected at the following locations:</p> <ol style="list-style-type: none"> <li>1) The same tap as the original positive result;</li> <li>2) A tap within 5 taps upstream of the original positive tap;</li> <li>3) A tap within 5 taps downstream of the original positive tap;</li> <li>4) A tap within 5 taps either upstream or downstream of the original positive.</li> </ol> <p>Each set of four (4) repeat samples <u>must</u> be collected on the same day.</p>

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korteski, Director

Fred Smith, Sumar Investment Co.  
Buckeye Landscape Services  
Page -2-

If you have any questions, please contact me at (614) 728-3874.

Sincerely,

A handwritten signature in cursive script that reads "Ray Shesky".

Raymond Shesky  
Environmental Specialist II  
Division of Drinking and Ground Waters  
Central District Office

Enclosures

c: Toni Buchanan, DDAGW/CO  
Franklin County Health Department  
CDO File  
Angela Rae, Buckeye Landscape Services

RS/nsm 2557712 pos. not.