



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

OH2543212 DIGGER AND FINCH PWS

21 09/08/11 I



CERTIFIED MAIL # 91 7108 2133 3932 1838 4844

NOTICE OF VIOLATION - ACTION REQUIRED

September 8, 2011

Re: Franklin County
Digger and Finch PWS
Non-Community, Transient
PWS ID: OH2543212

Cathy Masters
3248 W Henderson Road
Columbus, OH 43220

**Subject: Violation of Total Coliform Maximum Contaminant Level (MCL)
During Third Quarter of 2011 (ACUTE)**

Digger And Finch PWS is in violation of the Maximum Contaminant Level (MCL) for Total Coliform established by Ohio Administrative Code (OAC), Rule 3745-81-14. Water samples have confirmed the presence of *E. colifecal* coliform in the drinking water. *Fecal coliforms and E. coli are bacteria whose presence indicates that the water may be contaminated with human or animal wastes.* This is an Acute MCL violation requiring immediate action.

IMMEDIATE ACTION REQUIRED:

1. **Consult with Ohio EPA within 24 hours** regarding public notice requirements. If you have not already received direction regarding this violation, contact the CDO at 614-728-3871.
2. **Issue the enclosed public notice within 24 hours** in accordance with OAC, Rule 3745-81-32 using one or more of the following methods to reach all persons served.
 - Hand delivery to persons served by the water system
 - Posting in conspicuous locations, such as bulletin boards, restrooms, drinking fountains, vending areas
 - Send to parents or guardians of children at schools or day care facilities
 - Another delivery method approved in writing by the director
 - Posted notices must remain in place for as long as the violation exists.
 - Posted notices must remain in place for as long as the violation exists, but in no case for less than seven (7) days (even if the violation is resolved). The language in italics on the enclosed public notice is mandatory and must be included, as written. Do not make changes to the public notice without consulting with Ohio EPA beforehand.

NOTE: Issuance of a Public Notice must be repeated every 30 days for as long as the violation exists, unless directed otherwise by the District Office. A verification form and a copy of the public notice stating the corrective measures completed to date must be submitted to the Ohio EPA.

3. **Investigate and eliminate the cause of bacterial contamination.** Special purpose samples may be collected to investigate the source of contamination or to verify elimination of the problem (these samples cannot be collected to comply with monitoring or MCL requirements; label samples as "special purpose").

Central District Office
50 West Town Street, Suite 700
P.O. Box 1049
Columbus, OH 43216-1049


614 | 728 3778
614 | 728 3898 (fax)
www.epa.ohio.gov

Cathy Masters
Page -2-

4. **Complete the enclosed verification form within 10 days of issuing the Public Notice** and mail it to Ohio EPA - CDO. Include a copy of each notice distributed, published or posted.
5. **Discontinue the Water Use Advisory** – The water use advisory shall remain in effect until one set of four (4) repeat samples is total coliform-negative. Notify the people served by the water system when the water use advisory is discontinued.
6. **Monitor with at least five (5) routine samples** in the month following a routine total coliform-positive result in accordance with OAC, Rule 3745-81-21(B)(7).

If you have any questions, contact this office at 614-728-3871.

Sincerely,



Mark Boden
Environmental Specialist II
Division of Drinking and Ground Waters
Central District Office

Enclosures: Tier 1 Public Notification
Public Notice, Instructions and Verification Form

c: Franklin County Health Department
Information Management Section, DDAGW/CO
District File Copy

MB/ct 2543212(Type21)3Q2011

*Hand Delivered
September 9, 2011*