



Environmental  
Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

OH4243112 COCHRANS LIT-LE LAMBS LEARNING CTR PV 52 03/03/11



March 3, 2011

Re: **Knox County**  
**Cochrans Lit-le Lambs Learning Center**  
**Transient Non-Community**  
**PWS ID #OH4243112**

Cochrans Lit-le Lambs Learning Center  
P.O. Box 745  
Centerburg, OH 43011

**Subject: Notice of Violation - Failure to Sample Drinking Water as Required for Lead and Copper**

Your public water system is in violation of Rule 3745-81-80 through 3745-81-89 of the Ohio Administrative Code for failure to comply with the lead and copper monitoring requirements:

<b>Monitoring Period:</b>	<b>June - September 2010</b>
<b>Required Sampling:</b>	<b>5 samples for each lead and copper</b>
<b>Sample Results Submitted:</b>	<b>None</b>

<b>Actions required as a result of the above violation</b>	
Step 1	Collect and analyze the required number of lead and copper tap samples during June - September 2011. Based upon the reported population, you are required to collect a minimum of 5 lead and copper samples. Report results on the enclosed forms 5105, 5106 and 5107 by October 10, 2011.
Step 2	<p>Within 30 days issue public notice of the violation in accordance with rule 3745-81-32 of the Ohio Administrative Code by the following methods</p> <ol style="list-style-type: none"> <li>1. continuous posting, mail, or other direct delivery; and</li> <li>2. if necessary, the system must also use any other method reasonably calculated to reach all persons</li> </ol> <p>The language in <i>italic</i> on the attached public notice is mandatory and must be included as written.</p>

Cochrans Little Lambs Learning Center  
Page -2-

If you have any questions, please contact me at (614) 728-3871.

Sincerely,



Mark Boden  
Environmental Specialist II  
Division of Drinking and Ground Waters  
Central District Office

Enclosures

c: Knox County Health Department  
Toni Buchanan, DDAGW/CO  
CDO File

MB/ct 4243112 52(Jun Sep)