



State of Ohio Environmen.

* 0 H 4 5 5 7 3 1 2 8 6 6 7 4 0 8 *

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

December 11, 2007

Re: **Licking County
Buckeye Lake Valero
Transient Non-Community
PWS ID #4557312
CERTIFIED MAIL # 91 7108 2133 3932 4450 7071**

Owner
Buckeye Lake Valero
10905 Hebron Road
P.O. Box 1245
Buckeye Lake, OH 43008

Subject: Notice of Violation of Maximum Contaminant Level for Total Coliform Bacteria (ACUTE, MONTHLY & Failure to Monitor with four repeat samples)

During October 2007, your public water system incurred **acute** and **monthly** violations of rule 3745-81-14 of the Ohio Administrative Code (OAC) and a **monitoring** violation of rule 3745-81-21 (B)(1) of the OAC.

Acute and monitoring violations occur when four (4) total coliform bacteria repeat samples are not collected as required. **As a result of this violation, you are required to issue a water use advisory. Water must first be boiled prior to being used for potable purposes or bottled water must be provided.**

A monthly violation occurs when more than one or greater than five percent of your samples within the month are total coliform-positive.

Actions required as a result of the above violation	
Step 1	<p>Within 24 hours, consult with Ohio EPA and issue the attached public notice in accordance rule with 3745-81-32 of the Ohio Administrative Code using the following method(s) to reach all persons served by the public water system:</p> <p>Posting in conspicuous locations (restrooms, drinking fountains, vending areas, restaurants, bulletin boards, etc.)</p> <p>The language in italics on the attached public notice is mandatory and must be included as written.</p>
Step 2	Immediately initiate an investigation to determine and eliminate the cause and extent of bacterial contamination.
Step 3	Fill out the attached verification form and send along with a copy of the public notification issued within 10 days to the District Office of Ohio EPA.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Owner
Buckeye Lake Valero
Page -2-

Step 4	Lifting the Advisory - The public notice water use advisory shall remain in effect until you obtain one complete set of four (4) total coliform-negative (contain no coliforms) repeat samples. Clearly mark each repeat sample slip as "repeat sample". It is advisable to notify your customers when the problem is corrected.
Step 5	Because you are required to monitor with at least five (5) samples in the next month following any total coliform-positive result you must take at least five (5) total coliform samples in November 2007.

If you have any questions, please contact me at (614) 728-3874.

Sincerely,



Raymond Shesky
Environmental Specialist II
Division of Drinking and Ground Waters
Central District Office

Enclosures

c: Licking County Health Department
Toni Buchanan, DDAGW/CO
CDO File