

SIGNATURE RECEIVED



State of Ohio Environmental Protection Agency

Central District Office

COPY

STREET ADDRESS:

MAILING ADDRESS:

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.usP.O. Box 1049  
Columbus, OH 43216-1049

August 28, 2007

Re: Licking County  
McDonalds Restaurant #4326  
Transient Non-Community  
PWS ID #4543512  
CERTIFIED 91 7108 2133 3932 4450 9396Owner  
McDonalds Restaurant #4326  
P O Box 1214  
Buckeye Lake, OH 43008Subject: Notice of Violation of Monthly Maximum Contaminant Level  
for Total Coliform BacteriaYour public water system incurred a **monthly** violation of rule 3745-81-14 of the Ohio Administrative Code (OAC) in July 2007.

A monthly violation of rule 3745-81-14 occurs when more than one or greater than five percent of your samples within the month were total coliform-positive.


Actions required as a result of the above violation	
Step 1	Immediately initiate an investigation to determine and eliminate the cause and extent of bacterial contamination.
Step 2	Within 30 days issue the attached public notice of the violation in accordance with rule 3745-81-32 of the Ohio Administrative Code by the following method(s) to reach all persons served by the public water system:  Posting in conspicuous locations (restrooms, drinking fountains, vending areas, restaurants, bulletin boards, etc.).  The language in italics on the attached public notice is mandatory and must be included as written.
Step 3	Fill out the attached verification form and send along with a copy of the public notification issued within 10 days of the issuance of the public notice to the Central District Office of the Ohio EPA.
Step 4	Because you are required to monitor with at least five (5) samples in the next month following any total coliform-positive result you must take at least five (5) total coliform samples in August 2007.

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Kortleski, Director

Owner  
McDonalds Restaurant #4326  
Page -2-

If you have any questions, please contact me at (614) 728-5034.

Sincerely,

A handwritten signature in black ink, appearing to read "Linda Olvera". The signature is stylized and includes a long, sweeping flourish that extends to the right.

Linda Olvera  
Environmental Specialist II  
Division of Drinking and Ground Waters  
Central District Office

Enclosures

c: Toni Buchanan, DDAGW/CO  
Licking County Health Department  
CDO File

LO/nsm 4543512 NOV22 July 2007