



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.usP.O. Box 1049
Columbus, OH 43216-1049

November 13, 2007

**Re: Licking County
Beechridge Lounge
Transient Non-Community
PWS ID #4538112**

George Protopopow
Owner
Beechridge Lounge
HC-1 Box 84-B
Bradford, PA 16701

**Subject: Notice of Violation - Failure to Sample Drinking Water as Required
for Total Coliforms**

Your public water system is in violation of Rule 3745-81-21 of the Ohio Administrative Code for failure to comply with the coliform monitoring requirements:

Monitoring Period:	July - September 2007
Required Coliform Sampling:	At least 1 sample each calendar quarter.
Sample Results Submitted:	NONE

Actions required as a result of the above violation	
Step 1	<p>Within 30 days issue public notice of the violation in accordance with rule 3745-81-32 of the Ohio Administrative Code by the following methods:</p> <ol style="list-style-type: none"> 1. Continuous posting, mail, or other direct delivery; and 2. If necessary, the system must also use any other method reasonably calculated to reach all persons. <p>The language in <i>italics</i> on the attached public notice is mandatory and must be included as written.</p>
Step 2	<p>Within ten (10) days of completing Step 1 above, fill out the attached verification form and send along with a copy of the public notification issued to the District Office of the Ohio EPA.</p>

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

George .Protopopow
Owner
Beechridge Lounge
Page -2-

If you have any questions, please contact me at (614) 728-3874.

Sincerely,

A handwritten signature in cursive script that reads "Ray Shesky".

Raymond Shesky
Environmental Specialist II
Division of Drinking and Ground Waters
Central District Office

Enclosures

c: Toni Buchanan, DDAGW/CO
Licking County Health Department
CDO File
Beechridge Lounge, Heath OH

RS/nsm 4538112 NOV 23or24 July-Sept 2007