

# SIGNATURE RE Ohio



OH4931912 FUELCO INC.

25 09/20/07 I

State of Ohio Environm

STREET ADDRESS:

Central Dis

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

TELE: (614) 728-3778  
www.epa.i



September 20, 2007

**Re: Madison County  
Fuelco Inc.  
Transient Non-Community  
PWS ID #4931912  
CERTIFIED #91 7108 2133 3932 4450 9501**

Lowell B Rader  
Fuelco Inc.  
12765 SR 56 SE  
Mt Sterling, OH 43143

**Subject: Notice of Violation of Maximum Contaminant Level for Total Coliform Bacteria (ACUTE, MONTHLY & Failure to Monitor with four repeat samples)**

During July - September 2007, your public water system incurred **acute** and **monthly** violations of rule 3745-81-14 of the Ohio Administrative Code (OAC) and a **monitoring** violation of rule 3745-81-21 (B)(1) of the OAC.

**Acute and monitoring violations** occur when four (4) total coliform bacteria repeat samples are not collected as required. **As a result of this violation, you are required to issue a water use advisory. Water must first be boiled prior to being used for potable purposes or bottled water must be provided.**

**A monthly violation** occurs when more than one or greater than five percent of your samples within the month are total coliform-positive.

Actions required as a result of the above violation	
Step 1	<p><b>Within 24 hours</b>, consult with Ohio EPA and issue the attached public notice in accordance rule with 3745-81-32 of the Ohio Administrative Code using the following method(s) to reach all persons served by the public water system:</p> <p>Posting in conspicuous locations (restrooms, drinking fountains, vending areas, restaurants, bulletin boards, etc.)</p> <p>The language in italics on the attached public notice is mandatory and must be included as written.</p>
Step 2	Immediately initiate an investigation to determine and eliminate the cause and extent of bacterial contamination.
Step 3	Fill out the attached verification form and send along with a copy of the public notification issued within 10 days to the District Office of the Ohio EPA.

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korteski, Director

Lowell B Rader  
Fuelco Inc.  
Page -2-

Step 4	Lifting the Advisory - The public notice water use advisory shall remain in effect until you obtain one complete set of four (4) total coliform-negative (contain no coliforms) repeat samples. Clearly mark each repeat sample slip as "repeat sample". It is advisable to notify your customers when the problem is corrected.
Step 5	Because you are required to monitor with at least five (5) samples in the next month following any total coliform-positive result you must take at least five (5) total coliform samples in October 2007.

If you have any questions, please contact me at (614) 728-5033.

Sincerely,



Susan Hampton  
Environmental Specialist III  
Division of Drinking and Ground Waters  
Central District Office

Enclosures

c: Toni Buchanan, DDAGW/CO  
Madison County Health Department  
CDO File  
Fuelco Inc., Manager, Greg Begley, 12765 Sr 56 Se, Mt Sterling, OH 43143

SH/nsm 4931912 NOV21 22 25or26 July-Sept 2007