

8/27/08



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

P.O. Box 1049  
Columbus, OH 43216-1049

CERTIFIED MAIL # 91 7108 2133 3932 4450 3127

August 25, 2008

Re: **Morrow County  
Mount Gilead VFW Public Water System  
Transient Noncommunity Water System  
PWS ID: OH5941412**

Mr. Steve Burton  
Mount. Gilead VFW Post 8054  
P.O. Box 273  
Mount Gilead, OH 43338

Re: **Notice of Violation for Failure to Respond to a Significant Deficiency**

Dear Mr. Burton:

This letter is notification that the Mount Gilead VFW has not complied with requirements issued during this Agency's last survey performed on May 22, 2008, in violation of rule 3745-81-60 of the Ohio Administrative Code. You were notified in correspondence dated June 3, 2008 to respond in writing no later than 45 days, with time frames for:

- 1) Verifying there is more than 25 feet of well casing below grade;
- 2) Bringing the well out of the pit at least 12 inches above grade;
- 3) Welding or threading the casing extension onto the well;
- 4) Installing a screened and vented well cap;
- 5) Returning a completed well construction worksheet (or well log) to this office;
- 6) Sending us a copy of your completed sample siting plan;
- 7) Keeping the lid on the potassium permanganate day tank;
- 8) Returning a copy of the public (and verification form) notice given during the survey to this office;
- 9) Following the sampling schedule given during the survey, and
- 10) Using only NSF/ANSI certified salt in your softener.


The water system must respond in writing within 15 days from the date of this letter with the required information. Failure to comply may result in further enforcement action. You may notify me in writing via email at [mark.boden@epa.state.oh.us](mailto:mark.boden@epa.state.oh.us) or use the fax number or address provided in the letterhead.

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

Mr. Steve Burton  
Mount Gilead VFW Post 8054  
Page -2-

If you have any questions, please contact me at 614-728-3871.

Sincerely,



Mark Boden  
Environmental Specialist  
Division of Drinking and Ground Waters  
Central District Office

c: Morrow County Health Department  
DDAGW/CO  
Kenneth Baughman, DDAGW Enforcement/CO

MB/c Mount GileadVFWRTC