



**Environmental  
Protection Agency**

John E. Kasich, Governor

Frank LaRose, Lt. Governor

Joseph P. Kelly, Director

February 6, 2012

RE: SUMMIT COUNTY  
LIFE CENTER PLUS FITNESS CENTER  
NTNC WATER SYSTEM  
PWS ID #OH7733512

**VIOLATION NOTIFICATION**

Mr. Jim Clark, General Manager  
Life Center Plus Fitness Center  
5133 Darrow Road  
Hudson, OH 44236

**Subject: Failure to Perform and Submit Water Quality Parameters/Corrosion  
Control Recommendation/Source Water Treatment  
Recommendation/Detail Plans for Corrosion Control Equipment**

Dear Mr. Clark:

This letter is notification that the **Life Center Plus Fitness Center** water system remains in violation of the Ohio Administrative Code (OAC) for failure to perform Lead and Copper Water Quality Parameter and Entry Point Monitoring, and for failure to submit a Corrosion Control/Source Water Treatment Recommendation and Detail Plans as specified in OAC rules 3745-81-80 through 3745-81-89.

In order to return to compliance and avoid any further violations, you must complete the following:

1. As soon as possible, monitor with a minimum of two samples for each applicable water quality parameter from:
  - A. Each entry point to the distribution system; and
  - B. One site in the distribution system.

The parameters to measure are pH, water temperature, alkalinity, calcium, conductivity, orthophosphate (when a phosphate inhibitor is used), and silica (when a silicate-containing inhibitor is used).

LIFE CENTER PLUS FITNESS CENTER  
FEBRUARY 6, 2012  
PAGE 2 OF 2

In addition, monitor with a minimum of one sample for lead and copper at each entry point to the distribution system. Report the results to us on the enclosed Form 5108 within 30 days.

Issue the enclosed public notice and return a copy and the verification form to this office as soon as possible.

2. Submit the required Corrosion Control Recommendation and Detail Plans for optimal corrosion control treatment and equipment within 10 days of this notice.
3. Submit a Source Water Treatment Recommendation within 10 days of this notice.

If you have any questions regarding this letter, please contact me at (330) 963-1227.

Sincerely,



Ursula Musselman  
Environmental Specialist  
Division of Drinking and Ground Waters

UM:ds

enclosures: 5108 Form, Public Notice and Verification Form

cc: Dan Roberts, Life Center Plus Fitness Center, Maintenance  
Kim Eppers, Ohio EPA, DDAGW, NEDO