



State of Ohio Envir OH6100403 PURE WATER SYSTEM 2 PWS 2456 02 04/24/08

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 644-
www.



* 0 H 6 1 0 0 4 0 3 6 7 3 0 6 0 8 *

NOTICE OF VIOLATION – ACTION REQUIRED

April 24, 2008

CERTIFIED MAIL

91 7108 2133 3931 0972 8672

Pure Water System 2
Pure Water System 2
Po BOX 195,
Caldwell, OH 43724

Noble County
Pure Water System 2
Public Community PWS
PWS ID: OH6100403
Facility ID: N/A

Subject: Violation of Maximum Contaminant Level for TOTAL HALOACETIC ACIDS (HAA5)

Pure Water System 2 is in violation for exceeding the maximum contaminant level (MCL) standard of 0.060 MG/L as established in the Ohio Administrative Code (OAC) section 3745-81-12 for TOTAL HALOACETIC ACIDS (HAA5). Compliance with the MCL is based on a running annual average. The annual average for TOTAL HALOACETIC ACIDS (HAA5) during the Second Quarter of 2007 time period was 0.062 MG/L and during the Fourth Quarter of 2007 time period was 0.062 MG/L.

To address the MCL violation, Pure Water System 2 is required to take the following actions:

5. Notify your customers within 30 days using the enclosed instructions and public notice.
6. Complete and send a verification form with a copy of the public notice to the above mailing address within ten days after issuance.
7. Perform quarterly monitoring for TOTAL HALOACETIC ACIDS (HAA5) during each calendar quarter (January 1 – March 31; April 1 – June 30; July 1 – September 30; October 1 to December 31).
8. Consult with your Ohio EPA district representative to discuss your options for coming into compliance and establishing a compliance schedule or comply with any existing enforcement action that has been issued to you.

Your prompt attention to this matter is greatly appreciated. Continued noncompliance may lead to enforcement actions. If you have any questions or wish to change the public notice, please call me at (614) 644-2752.

Sincerely,

Sarah Byerly
Division of Drinking and Ground Waters
Enclosure: Public Notice, Verification Form
cc: Manager; SEDO District: DIV OF DRINKING AND GROUND WATER

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korteski, Director

DRINKING WATER NOTICE

Pure Water System 2 Has Levels of TOTAL HALOACETIC ACIDS (HAA5) Above Drinking Water Standards

Our water system recently violated the maximum contaminant level (MCL) for TOTAL HALOACETIC ACIDS (HAA5). The average level of TOTAL HALOACETIC ACIDS (HAA5) during the Second Quarter of 2007 time period was 0.062 MG/L and during the Fourth Quarter of 2007 time period was 0.062 MG/L.

What should I do?

- **You do not need to use an alternative (e.g., bottled) water supply.** However, if you have specific health concerns, consult your doctor.

What does this mean?

The levels detected do not pose an immediate risk to your health. However, some people who drink water containing TOTAL HALOACETIC ACIDS (HAA5) in excess of the MCL over many years could experience skin damage or problems with their circulatory system, and may have an increased risk of getting cancer.

What is being done?

We are investigating and taking the necessary steps to correct the problem as soon as possible.

Additional information may be obtained by contacting:

Contact Person: _____

Phone Number: _____

Mailing Address: _____

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

PWSID: OH6100403 Facility ID: N/A Date Distributed: _____