



State of Ohio E

OH6400411 NEW LEXINGTON

2950

02 08/31/07

STREET ADDRESS:

Lazarus Government Center
50 W Town Street, Suite 700
Columbus, OH 43215

TELE: (614) 6



ESS:
nter
1049
1049

August 31, 2007

Re: Perry County
New Lexington City PWS
Community Water System
PWS ID: OH6400411

CERTIFIED MAIL

NEW LEXINGTON, CITY OF
125 SOUTH MAIN ST.
NEW LEXINGTON, OH 43764

RE: TRIHALOMETHANES, TOTAL (TTHM) MAXIMUM CONTAMINANT LEVEL EXCEEDANCE

Dear Public Water System Owner:

This letter is notification that your public water system is in violation of rule 3745-81-12 of the Ohio Administrative Code (OAC). New Lexington City PWS has exceeded the maximum contaminant level (MCL) for TTHM within the April 1 through June 30, 2007 time period.

Paragraph B of rule 3745-81-12 establishes an MCL of 0.080 milligrams per liter (mg/L) for TTHM. Compliance with the MCL is based on the running annual average of four consecutive quarters of samples. The current running annual average for TTHM is 0.098 mg/L.

As a result of this violation, rule 3745-81-32 of the OAC requires that a public notice be issued by your facility informing your consumers of the violation. Included with this violation is a public notice containing the mandatory health effects language that must appear in the notice. If you wish to make additional statements in the notice, this office must be contacted first. The public notice must be issued within 30 days as specified in the enclosed "Public Notice Instructions and Verification Form for Community Public Water Systems with Tier 2 Violations". Please complete and return this form along with a copy of the public notice, once it is issued.

New Lexington City PWS public water system is required to continue monitoring according to your most recent Chemical Monitoring Distribution Schedule. For questions concerning the public notice requirement, please contact me at (614) 644-2752.

Sincerely,

Sarah E. Byerly
Compliance Assurance Section
Division of Drinking and Ground Waters

Enclosures: Public Notice and Verification Form for Tier 2 Violations

cc: Superintendent/Manager; SEDO, DDAGW; DDAGW; Perry County Health Department

DRINKING WATER NOTICE

New Lexington City PWS Has Levels of Trihalomethanes, total Above Drinking Water Standards

Our water system recently violated the maximum contaminant level (MCL) for Trihalomethanes, total (TTHM). The sample(s) collected on May 1, 2007 show TTHM at 0.078 mg/L. The average level of TTHM over the last year was 0.098 mg/L. The standard for TTHM is 0.080 mg/L.

What Should I Do?

You do not need to use an alternative (e.g., bottled) water supply. However, if you have specific health concerns, consult your doctor.

What Does This Mean?

The levels detected do not pose an immediate risk to your health. However, some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous system, and may have an increased risk of getting cancer.

What Is Being Done?

We are investigating and taking the necessary steps to correct the problem as soon as possible.

Additional information may be obtained by contacting New Lexington City PWS at:

Contact Person: _____

Phone Number: _____

Mailing Address: _____

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.