



State of Ohio Enviro

OH6433512

LIVING WORD CHURCH

2950

27 12/03/08

STREET ADDRESS:

Lazarus Government Center
50 W Town Street, Suite 700
Columbus, OH 43215

TEI E: (614) 644-302
www.ep



December 3, 2008

LIVING WORD CHURCH
3860 STATE ROUTE 37 W.
P.O. BOX 450
JUNCTION CITY, OH 43748

Re: PERRY COUNTY
LIVING WORD CHURCH
Nontransient Noncommunity Water System
PWS ID: OH6433512

NOTICE OF VIOLATION - ACTION REQUIRED

Subject: Failure to Monitor Drinking Water

Living Word Church is in violation of Ohio Administrative Code Rule 3745-81-24 for failing to monitor your drinking water during the July 1, 2008 to September 30, 2008 monitoring period and/or report results for the following contaminants: TOTAL TRIHALOMETHANES (TTHM)

In order to return to compliance, Living Word Church must take the following actions:

1. Immediately collect a sample of your drinking water from the maximum residence time (location in system where age of water is oldest).
2. Submit the sample for analysis to a certified laboratory on the enclosed list.
3. Notify your customers using the enclosed instructions and public notice.
4. Complete and return the enclosed verification form to this office.

Your prompt attention to this matter is greatly appreciated. Continued noncompliance may lead to enforcement actions. If you have any questions or if the required sample was tested, please call me at (614) 644-2752.

Sincerely,

Sarah Byerly
Division of Drinking and Ground Waters

Enclosure: Public Notice; Public Notice Instructions and Verification Form; Laboratory List
cc: Superintendent/Manager; DDAGW-SEDO file; DDAGW-CO file

