



State of Oh OH6537612 FOXFIRE GOLF CLUB

1005 02 03/05/09

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE



RESS:

xx 1049
16-1049

NOTICE OF VIOLATION – ACTION REQUIRED

March 05, 2009

CERTIFIED MAIL

Foxfire Golf Club
Foxfire Golf Club
10799 State Route 104,
Lockbourne, OH 43137

Pickaway County
Foxfire Golf Club
Non Transient Non Community PWS
PWS ID: OH6537612
Facility ID: 6557227

Subject: Violation of Maximum Contaminant Level for ARSENIC

Foxfire Golf Club is in violation for exceeding the maximum contaminant level (MCL) standard of 0.010 MG/L as established in the Ohio Administrative Code (OAC) section 3745-81-11 for ARSENIC. Compliance with the MCL is based on a running annual average. The annual average for ARSENIC during the Fourth Quarter of 2008 time period is 0.014 MG/L.

To address the MCL violation, Foxfire Golf Club is required to take the following actions:

- Notify your customers within 30 days using the enclosed instructions and public notice.
- Complete and send a verification form with a copy of the public notice to the above mailing address within ten days after issuance.
- Perform quarterly monitoring for ARSENIC during each calendar quarter (January 1 – March 31; April 1 – June 30; July 1 – September 30; October 1 to December 31).
- Consult with your Ohio EPA district representative to discuss your options for coming into compliance and establishing a compliance schedule or comply with any existing enforcement action that has been issued to you.

Your prompt attention to this matter is greatly appreciated. Continued noncompliance may lead to enforcement actions. If you have any questions or wish to change the public notice, please call me at (614) 644-2752.

Sincerely,

Kathleen Pinto
Division of Drinking and Ground Waters

Enclosure: Public Notice, Verification Form

cc: Central District Manager, Pickaway County Health Dept.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

OhioEPA

State of Ohio Environmental Protection Agency

Division of Drinking Water & Ground Water(DW)

Warrior Government Center

P.O. Box 1049

Columbus, Ohio 43216-1049

EPA - 5026 (Rev.11/98)



JUN 26 AM 9:07

*Resent UPS
Ground 3 day
6-26-09*

FOXFIRE GOLF CLUB
10799 STATE ROUTE 104
LOCKBOURNE, OH 43137



NIXIE 490 SE 1 70 06/25/09

RETURN TO SENDER
NO MAIL RECEIPTABLE
UNABLE TO FORWARD

EC: 43216104949 *0646-07091-25-29

43216@1049



5-2

CERTIFIED MAIL




91 7108 2133 3931 0973 6693



02 1M
0004264848 JUN 12 2009
MAILED FROM ZIP CODE 43215

\$ 04.34⁰



PLACE STICKER AT TOP OF ENVELOPE TO THE RIGHT
OF THE RETURN ADDRESS. FOLD AT DOTTED LINE