



STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 644-2
www.e



NOTICE OF VIOLATION – ACTION REQUIRED

August 28, 2009

CERTIFIED MAIL

Lloyd Kinzie
Precision Wood Products, Inc. PWS
2456 Aukerman Creek Rd, Po Box 10
Camden, OH 45311

Preble County
Precision Wood Products, Inc. PWS
Transient Non-Community PWS
PWS ID: OH6837312
Facility ID: 6861028

Subject: Violation of Maximum Contaminant Level for ARSENIC and monitoring violation
Precision Wood Products, Inc. PWS is in violation for exceeding the maximum contaminant level (MCL) standard of 0.010 MG/L as established in the Ohio Administrative Code (OAC) section 3745-81-11 for ARSENIC. Compliance with the MCL is based on a running annual average. The annual average for ARSENIC during the Second Quarter of 2009 time period is 0.018 MG/L.

Precision Wood Products is also in violation of OAC, section 3745-81-23 for failure to comply with quarterly arsenic monitoring for the Second Quarter of 2009.

When these violations occurred, your PWS was designated as a non-transient non-community. Although your PWS is now designated as a transient non-community water system, you are still required to public notice for these violations.

To address these violations, Precision Wood Products, Inc. PWS is required to take the following actions:

1. Notify your customers within 30 days using the enclosed instructions and public notice.
2. Complete and send a verification form with a copy of the public notice to the above mailing address within ten days after issuance.
3. Refer to the August 26, 2009 letter from Kirk Leifheit regarding action necessary for coming into compliance.

Your prompt attention to this matter is greatly appreciated. If you have any questions or wish to change the public notice, please call me at (614) 644-2752.

Sincerely,

Kathleen Pinto
Compliance Assurance Section
Division of Drinking and Ground Waters

Enclosure: Public Notice; Public Notice Instructions and Verification Form
cc: Manager; DDAGW file; SWDO file; Preble County Health Department

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korieski, Director

DRINKING WATER NOTICE

Precision Wood Products, Inc. PWS Has Levels of ARSENIC Above Drinking Water Standards

Our water system recently violated the maximum contaminant level (MCL) for ARSENIC. The average level of ARSENIC over the last four quarters was 0.018 MG/L. The standard for ARSENIC is 0.010 MG/L.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not your drinking water meets health standards. During the Second Quarter of 2009 we did not monitor or test for arsenic, and therefore cannot be sure of the quality of your drinking water during that time.

What should I do?

- You do not need to use an alternative (e.g., bottled) water supply. However, if you have specific health concerns, consult your doctor.

What does this mean?

The levels detected do not pose an immediate risk to your health. However, some people who drink water containing arsenic in excess of the MCL over many years could experience skin damage or problems with their circulatory system, and may have an increased risk of getting cancer..

What is being done?

We are investigating and taking the necessary steps to correct the problem as soon as possible.

Additional information may be obtained by contacting:

Contact Person: _____

Phone Number: _____

Mailing Address: _____

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

Date Distributed: _____

PWSID: OH6837312 Facility ID: 6861028
Monitoring Period: Second Quarter of 2009

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director