



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

OH7400712 FOSTORIA MOBILE ESTATES 1010 03 03/21/11



March 21, 2011

NOTICE OF VIOLATION - ACTION REQUIRED

Joe Raineri
Fostoria Mobile Estates
Po Box 398,
Bath, OH 44210

Seneca County
Fostoria Mobile Estates
COMMUNITY PWS
PWS ID: OH7400712

Subject: Failure to Monitor Drinking Water

Fostoria Mobile Estates is in violation of Ohio Administrative Code Rule (OAC) 3745-81-23 for failing to monitor your drinking water during the January 1 2008 to December 31, 2010 monitoring period and/or report results for the following contaminants: Antimony, Barium, Beryllium, Cadmium, Chromium, Fluoride, Cyanide, Mercury, Nickel, Selenium, Thallium.

In order to return to compliance, Fostoria Mobile Estates must take the following actions:

1. Immediately collect a sample of your drinking water from the entry point (first tap after treatment).
2. Submit the sample for analysis to a certified laboratory on the enclosed list.
3. Instruct the laboratory to report the results to Ohio EPA for compliance.

We have received verification that the public was notified of this violation.

Your prompt attention to this matter is greatly appreciated. Continued noncompliance may lead to enforcement actions. If you have any questions, or if the required sample analysis was performed, please call me at (614) 644-2752.

Sincerely,

Kathleen Pinto

Division of Drinking and Ground Waters

Enclosure: Laboratory List

cc: Manager; DDAGW NWDO file; DDAGW CO file

