



STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 644-2752
www.epa



NOTICE OF VIOLATION – ACTION REQUIRED

May 13, 2008

CERTIFIED MAIL

Fostoria Mobile Estates
Fostoria Mobile Estates
5473 N Twp Rd 63, Po BOX 400
Fostoria, OH 44830

Seneca County
Fostoria Mobile Estates
Public Community PWS
PWS ID: OH7400712
Facility ID: 7458091

Subject: Violation of Maximum Contaminant Level for ARSENIC

Fostoria Mobile Estates is in violation for exceeding the maximum contaminant level (MCL) standard of 0.010 MG/L as established in the Ohio Administrative Code (OAC) section 3745-81-11 for ARSENIC. Compliance with the MCL is based on a running annual average. The annual average for ARSENIC during the First Quarter of 2008 time period is 0.013 MG/L.

To address the MCL violation, Fostoria Mobile Estates is required to take the following actions:

- 25. Notify your customers within 30 days using the enclosed instructions and public notice.
- 26. Complete and send a verification form with a copy of the public notice to the above mailing address within ten days after issuance.
- 27. Perform quarterly monitoring for ARSENIC during each calendar quarter (January 1 – March 31; April 1 – June 30; July 1 – September 30; October 1 to December 31).
- 28. Consult with your Ohio EPA district representative to discuss your options for coming into compliance and establishing a compliance schedule or comply with any existing enforcement action that has been issued to you.

Your prompt attention to this matter is greatly appreciated. Continued noncompliance may lead to enforcement actions. If you have any questions or wish to change the public notice, please call me at (614) 644-2752.

Sincerely,

Kathleen Pinto
Division of Drinking and Ground Waters

Enclosure: Public Notice, Verification Form

cc: Manager, NWDO, DIV OF DRINKING AND GROUND WATER

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director



State of Ohio Environmental Protection Agency

Division of Drinking Water & Ground Waters (DW)

Lazarus Government Center

P.O. Box 1049

Columbus, Ohio 43216-1049

EPA - 5026 (Rev.6/99)

RECEIVED
DWA

JUL 14 AM 10:35

6-19 ✓
6-24 ✓
7-5 ✓



91 7108 2133 3931 0972 7965



UNITED STATES POSTAGE

02 1A \$ 03.12⁰
0004349327 JUN 17 2008
MAILED FROM ZIP CODE 43215

JOE RAINERI
FOSTORIA MOBILE ESTATES
PO BOX 398
BATH OH 44210



NIXIE

443 SE 1

77 07/08/08

RETURN TO SENDER
UNCLAIMED
UNABLE TO FORWARD

BC: 43216104949

*2073-01916-17-37

44210494949

