



State of Ohio Environ

OH7501012

NORTHBROOK MHP

1005

02 05/13/08

STREET ADDRESS:

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

TELE: (614) 644-2721  
www.epa



\* 0 H 7 5 0 1 0 1 2 7 5 7 9 9 0 8 \*

**NOTICE OF VIOLATION – ACTION REQUIRED**

May 13, 2008

CERTIFIED MAIL

Northbrooke MHP  
Northbrook MHP  
2805 Wapakoneta Ave., Lot 92,  
Sidney, OH 45365

Shelby County  
Northbrook MHP  
Public Community PWS  
PWS ID: OH7501012  
Facility ID: 7558203

**Subject: Violation of Maximum Contaminant Level for ARSENIC**

Northbrook MHP is in violation for exceeding the maximum contaminant level (MCL) standard of 0.010 MG/L as established in the Ohio Administrative Code (OAC) section 3745-81-11 for ARSENIC. Compliance with the MCL is based on a running annual average. The annual average for ARSENIC during the First Quarter of 2008 time period is 0.014 MG/L.

To address the MCL violation, Northbrook MHP is required to take the following actions:

41. Notify your customers within 30 days using the enclosed instructions and public notice.
42. Complete and send a verification form with a copy of the public notice to the above mailing address within ten days after issuance.
43. Perform quarterly monitoring for ARSENIC during each calendar quarter (January 1 – March 31; April 1 – June 30; July 1 – September 30; October 1 to December 31).
44. Consult with your Ohio EPA district representative to discuss your options for coming into compliance and establishing a compliance schedule or comply with any existing enforcement action that has been issued to you.

Your prompt attention to this matter is greatly appreciated. Continued noncompliance may lead to enforcement actions. If you have any questions or wish to change the public notice, please call me at (614) 644-2752.

Sincerely,

Kathleen Pinto  
Division of Drinking and Ground Waters

Enclosure: Public Notice, Verification Form

cc: Manager; SWDO, DIV OF DRINKING AND GROUND WATER

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

# DRINKING WATER NOTICE

## Northbrook MHP Has Levels of ARSENIC Above Drinking Water Standards

Our water system recently violated the maximum contaminant level (MCL) for ARSENIC. The average level of ARSENIC over the last four quarters was 0.014 MG/L. The standard for ARSENIC is 0.010 MG/L.

### What should I do?

- **You do not need to use an alternative (e.g., bottled) water supply.** However, if you have specific health concerns, consult your doctor.

### What does this mean?

The levels detected do not pose an immediate risk to your health. However, some people who drink water containing ARSENIC in excess of the MCL over many years could experience skin damage or problems with their circulatory system, and may have an increased risk of getting cancer.

### What is being done?

We are investigating and taking the necessary steps to correct the problem as soon as possible.

Additional information may be obtained by contacting:

Contact Person: \_\_\_\_\_

Phone Number: \_\_\_\_\_

Mailing Address: \_\_\_\_\_

*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.*

PWSID: OH7501012    Facility ID: 7558203    Date Distributed: \_\_\_\_\_