



Environmental  
Protection Agency

Ted Strickland, Governor  
Lee Fisher, Lt. Governor  
Chris Kordeski, Director

OH7501312 LAKE VIEW VILLAGE MHP 1005 02 11/17/10



November 17, 2010

**NOTICE OF VIOLATION – ACTION REQUIRED**

CERTIFIED MAIL

Joy Sommer  
Lake View Village Mhp  
12550 State Route 362-W1,  
Minster, OH 45865

Shelby County  
Lake View Village Mhp  
Community PWS  
PWS ID: OH7501312  
Facility ID: 7558206

**Subject: Violation of Maximum Contaminant Level for ARSENIC**

Lake View Village Mhp is in violation for exceeding the maximum contaminant level (MCL) standard of 0.010 MG/L as established in the Ohio Administrative Code (OAC) section 3745-81-11 for ARSENIC. Compliance with the MCL is based on a running annual average. The annual average for ARSENIC during the Third Quarter of 2010 time period is 11 UG/L.

To address the MCL violation, Lake View Village Mhp is required to take the following actions:

1. Notify your customers within 30 days using the enclosed instructions and public notice.
2. Complete and send a verification form with a copy of the public notice to the above mailing address within ten days after issuance.
3. Perform quarterly monitoring for ARSENIC during each calendar quarter (January 1 – March 31; April 1 – June 30; July 1 – September 30; October 1 to December 31).
4. Consult with your Ohio EPA district representative to discuss your options for coming into compliance and establishing a compliance schedule or comply with any existing enforcement action that has been issued to you.

Your prompt attention to this matter is greatly appreciated. Continued noncompliance may lead to enforcement actions. If you have any questions or wish to change the public notice, please call me at (614) 644-2752.

Sincerely,

Kathleen Pinto,  
Compliance Assurance Section  
Division of Drinking and Ground Waters

Enclosure: Public Notice; Public Notice Instructions and Verification Form  
cc: Manager; DDAGW file; SWDO file; Shelby County Health Department

50 West Town Street, Suite 700  
P.O. Box 1049  
Columbus, OH 43216-1049

614 | 644 3020  
614 | 644 3184 (fax)  
www.epa.ohio.gov

# DRINKING WATER NOTICE

## Lake View Village Mhp Has Levels of ARSENIC Above Drinking Water Standards

Our water system recently violated the maximum contaminant level (MCL) for ARSENIC. The average level of ARSENIC over the last four quarters was 11 UG/L. The standard for ARSENIC is 0.010 MG/L.

### What should I do?

- **You do not need to use an alternative (e.g., bottled) water supply.** However, if you have specific health concerns, consult your doctor.

### What does this mean?

The levels detected do not pose an immediate risk to your health. However, some people who drink water containing arsenic in excess of the MCL over many years could experience skin damage or problems with their circulatory system, and may have an increased risk of getting cancer..

### What is being done?

We are investigating and taking the necessary steps to correct the problem as soon as possible.

Additional information may be obtained by contacting:

Contact Person: \_\_\_\_\_

Phone Number: \_\_\_\_\_

Mailing Address: \_\_\_\_\_

*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.*

Date Distributed: \_\_\_\_\_

PWSID: OH7501312 Facility ID: 7558206

Monitoring Period: Third Quarter of 2010

PUBLIC NOTICE INSTRUCTIONS AND VERIFICATION FORM FOR  
COMMUNITY PUBLIC WATER SYSTEMS WITH TIER 2 VIOLATIONS

NOV 12 2010

Southwest District

The owner or operator of a Community public water system with Tier 2 violation or situation shall notify the persons served by the public water system as soon as practical but no later than 30 days after the system learns of the violation. Public notice shall be repeated every 3 months as long as the violation or situation persists.

I HEREBY CERTIFY THAT THE PUBLIC WAS NOTIFIED BY THE FOLLOWING METHOD(S) INDICATED BELOW, AS DESCRIBED IN THE OHIO ADMINISTRATIVE CODE RULE 3745-81-32:

Required Method of Public Notification	Actual Method of Public Notification
<p><b>COMMUNITY WATER SYSTEMS -</b></p> <p>1. Must issue public notice by mail or other direct delivery to each customer and service connection (where known).</p> <p>2. May also post in conspicuous locations throughout the distribution system (must remain posted for as long as the violation exists, but at least 7 days).</p>	<p>1. Date of mailing/delivery: <u>10-12-10</u></p> <p>2.A. Dates of posting: _____</p> <p>2.B. Locations of posting: _____</p>
<p><b>ALL SYSTEMS -</b></p> <p>If the above methods do not reach all persons served, also use any other method reasonably calculated to reach other persons served by the system (e.g., publication in a local newspaper or newsletter, use of e-mail to notify employees or students, or delivery of multiple copies to central locations).</p>	<p>A. Method(s) _____</p> <p>B. Date(s) _____</p>

Please indicate below which public notice was used. INCLUDE A COPY OF THE PUBLIC NOTICE.

A public notice as provided was issued without changes.

A different public notice was issued.

PWS NAME: -Lake View Village MHP  
PWS ID: OH7501512  
Facility ID: 7558206  
County: Miami County  
Arsenic MCL, Average: 1st Qtr 09

Jeff Sommer 10/12/10  
Signature of Responsible Person Date

JEFF SOMMER  
Printed Name and Title of Responsible Person

For Ohio EPA use only:	
Date PN received:	<u>11-15-10</u>
PN acceptable: <input checked="" type="checkbox"/>	PN not acceptable: <input type="checkbox"/>

RECEIVED  
OHIO EPA

NOV 12 2010

# DRINKING WATER NOTICE

## Lake View Village MHP Has Southwest District Levels of ARSENIC Above Drinking Water Standards

We routinely monitor for the presence of drinking water contaminants. During the January 1- March 31, 2009 monitoring period, our water exceeded the maximum contaminant level (MCL) for ARSENIC. The average level of ARSENIC the four quarters beginning April 1, 2008 was 0.0110 mg/L. The standard for ARSENIC is 0.010 mg/L.

Additionally, we are required to post public notice when violations have occurred. During this same time period listed above, we did not post the required public notice.

### What Should I Do?

- *You do not need to use an alternative (e.g., bottled) water supply. However, if you have specific health concerns, consult your doctor.*
- *This is to inform you of a past violation at Lake View Village MHP, where notification may not have been communicated, where we showed levels of arsenic in the public drinking water system during the time period listed above, as required by the Ohio Environmental Protection Agency.*

### What does this mean?

The levels detected do not pose an immediate risk to your health. However, some people who drink water containing ARSENIC in excess of the MCL over many years could experience skin damage or problems with their circulatory system, and may have an increased risk of getting cancer.

### What is being done?

The water supplier is taking steps to ensure that these issues will be addressed in the future.

For more information, please contact JEFF SOMMER 412-628-3377  
name of contact phone number  
 or at 12550 STRT 362 MCMSTER OH  
mailing address 45865

*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.*

PWSID# OH7501312	Facility ID: 7558206
------------------	----------------------

Date Distributed: 10-12-10

RECEIVED  
NOV 15 2010  
OHIO EPA - DDAGW