



**Environmental Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

OH7501512 WEST LAKE VILLAGE MHP PWS 1005 02 02/16/11



February 16, 2011

**NOTICE OF VIOLATION – ACTION REQUIRED**

CERTIFIED MAIL

91 7108 2133 3937 1501 1113

Joy Sommer  
West Lake Village Mhp PWS  
12550 State Rte 362,  
Minster, OH 45865

Shelby County  
West Lake Village Mhp PWS  
Community PWS  
PWS ID: OH7501512  
Facility ID: 7558208

**Subject: Violation of Maximum Contaminant Level for ARSENIC**

West Lake Village Mhp PWS is in violation for exceeding the maximum contaminant level (MCL) standard of 0.010 MG/L as established in the Ohio Administrative Code (OAC) section 3745-81-11 for ARSENIC. Compliance with the MCL is based on a running annual average. The annual average for ARSENIC during the Fourth Quarter of 2010 time period is 0.011 MG/L.

To address the MCL violation, West Lake Village Mhp PWS is required to take the following actions:

1. Notify your customers within 30 days using the enclosed instructions and public notice.
2. Complete and send a verification form with a copy of the public notice to the mailing address below within ten days after issuance.
3. Perform quarterly monitoring for ARSENIC during each calendar quarter (January 1 – March 31; April 1 – June 30; July 1 – September 30; October 1 to December 31).
4. Consult with your Ohio EPA district representative to discuss your options for coming into compliance and establishing a compliance schedule or comply with any previously issued enforcement action.

Your prompt attention to this matter is greatly appreciated. Continued noncompliance may lead to additional enforcement actions. If you have any questions or wish to change the public notice, please call me at (614) 644-2752.

Sincerely,

Kathleen Pinto,  
Compliance Assurance Section  
Division of Drinking and Ground Waters

Enclosure: Public Notice; Public Notice Instructions and Verification Form  
cc: Manager; DDAGW file; SWDO file; Shelby County Health Department

# DRINKING WATER NOTICE

## West Lake Village Mhp PWS Has Levels of ARSENIC above Drinking Water Standards

Our water system recently violated the maximum contaminant level (MCL) for ARSENIC. The average level of ARSENIC over the last four quarters was 0.011 MG/L. The standard for ARSENIC is 0.010 MG/L.

### What should I do?

- **You do not need to use an alternative (e.g., bottled) water supply.** However, if you have specific health concerns, consult your doctor.

### What does this mean?

The levels detected do not pose an immediate risk to your health. However, some people who drink water containing arsenic in excess of the MCL over many years could experience skin damage or problems with their circulatory system, and may have an increased risk of getting cancer.

### What is being done?

We are investigating and taking the necessary steps to correct the problem as soon as possible.

Additional information may be obtained by contacting:

Contact Person: \_\_\_\_\_

Phone Number: \_\_\_\_\_

Mailing Address: \_\_\_\_\_

*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.*

Date Distributed: \_\_\_\_\_

PWSID: OH7501512 Facility ID: 7558208

Monitoring Period: Fourth Quarter of 2010