

**Environmental
Protection Agency**John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

February 16, 2011

NOTICE OF VIOLATION – ACTION REQUIRED**CERTIFIED MAIL**

91 7108 2133 3937 1501 1205

David Notman
Country Lawn Nursing Home
10608 Navarre Road Sw,
Navarre, OH 44662Stark County
Country Lawn Nursing Home
Community PWS
PWS ID: OH7601412
Facility ID: 7658282**Subject: Violation of Maximum Contaminant Level for ARSENIC**

Country Lawn Nursing Home is in violation for exceeding the maximum contaminant level (MCL) standard of 0.010 MG/L as established in the Ohio Administrative Code (OAC) section 3745-81-11 for ARSENIC. Compliance with the MCL is based on a running annual average. The annual average for ARSENIC during the Fourth Quarter of 2010 time period is 0.014 MG/L.

To address the MCL violation, Country Lawn Nursing Home is required to take the following actions:

1. Notify your customers within 30 days using the enclosed instructions and public notice.
2. Complete and send a verification form with a copy of the public notice to the mailing address below within ten days after issuance.
3. Perform quarterly monitoring for ARSENIC during each calendar quarter (January 1 – March 31; April 1 – June 30; July 1 – September 30; October 1 to December 31).
4. Consult with your Ohio EPA district representative to discuss your options for coming into compliance and establishing a compliance schedule or comply with any previously issued enforcement action.

Your prompt attention to this matter is greatly appreciated. Continued noncompliance may lead to additional enforcement actions. If you have any questions or wish to change the public notice, please call me at (614) 644-2752.

Sincerely,

Kathleen Pinto,
Compliance Assurance Section
Division of Drinking and Ground WatersEnclosure: Public Notice; Public Notice Instructions and Verification Form
cc: Manager; (DDAGW file); NEDO file; Stark County Health Department

DRINKING WATER NOTICE

Country Lawn Nursing Home Has Levels of ARSENIC above Drinking Water Standards

Our water system recently violated the maximum contaminant level (MCL) for ARSENIC. The average level of ARSENIC over the last four quarters was 0.014 MG/L. The standard for ARSENIC is 0.010 MG/L.

What should I do?

- **You do not need to use an alternative (e.g., bottled) water supply.** However, if you have specific health concerns, consult your doctor.

What does this mean?

The levels detected do not pose an immediate risk to your health. However, some people who drink water containing arsenic in excess of the MCL over many years could experience skin damage or problems with their circulatory system, and may have an increased risk of getting cancer.

What is being done?

We are investigating and taking the necessary steps to correct the problem as soon as possible.

Additional information may be obtained by contacting:

Contact Person: _____

Phone Number: _____

Mailing Address: _____

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

Date Distributed: _____

PWSID: OH7601412 Facility ID: 7658282

Monitoring Period: Fourth Quarter of 2010