



STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 644-2752
www.epa.ohio.gov



NOTICE OF VIOLATION – ACTION REQUIRED

July 22, 2009

CERTIFIED MAIL

91 7108 2133 3931 0972 3851

Randy Geitgey
Englewood Manor Apts.
5284 Everhard Rd NW
Canton, OH 44718

Stark County
Englewood Manor Apts.
Community PWS
PWS ID: 7601712
Facility ID: 7660598

Subject: Violation of Maximum Contaminant Level for Combined Radium-226 and Radium-228

Englewood Manor Apartments is in violation for exceeding the maximum contaminant level (MCL) standard of 5 pCi/L as established in the Ohio Administrative Code (OAC) section 3745-81-15 for combined Radium-226 and Radium-228. Compliance with the MCL is based on a running annual average. The annual average for combined Radium-226 and Radium-228 during the April 1 to June 30, 2009 time period is 5.6 pCi/L.

To address the MCL violation, Englewood Manor Apartments is required to take the following actions:

1. Notify your customers within 30 days using the enclosed instructions and public notice.
2. Complete and send a verification form with a copy of the public notice to the above mailing address within ten days after issuance.
3. Perform quarterly monitoring for radium-226 and radium-228 during each calendar quarter (January 1 – March 31; April 1 – June 30; July 1 – September 30; October 1 to December 31).
4. Consult with your Ohio EPA district representative to discuss your options for coming into compliance and establishing a compliance schedule.

Your prompt attention to this matter is greatly appreciated. Continued noncompliance may lead to enforcement actions. If you have any questions or wish to change the public notice, please call me at (614) 644-2752.

Sincerely,

Wendy Sheeran
Division of Drinking and Ground Waters

Enclosure: Laboratory List, Public Notice, Verification Form

cc: Manager; DDAGW-NEDO file; DDAGW-CO file; Stark Co. Health Dept.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

DRINKING WATER NOTICE

Englewood Manor Apartments Has Levels of Radium Above Drinking Water Standards

Our water system recently violated the maximum contaminant level (MCL) for combined Radium-226 and Radium-228. The average level of combined Radium-226 and Radium-228 over the last four quarters was 5.6 pCi/L. The standard for combined Radium-226 and Radium-228 is 5 pCi/L.

What should I do?

- **You do not need to use an alternative (e.g., bottled) water supply.** However, if you have specific health concerns, consult your doctor.

What does this mean?

The levels detected do not pose an immediate risk to your health. However, some people who drink water containing combined Radium-226 and Radium-228 in excess of the MCL over many years may have an increased risk of getting cancer.

What is being done?

We are investigating and taking the necessary steps to correct the problem as soon as possible.

Additional information may be obtained by contacting:

Contact Person: _____

Phone Number: _____

Mailing Address: _____

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

PWSID: OH7601712 Facility ID: 7660598 Date Distributed: _____