



STREET ADDRESS:

Lazarus Government Center
50 W Town Street, Suite 700
Columbus, OH 43215

TELE: (614) 644-3020



August 27, 2007

CERTIFIED MAIL

91 7108 2133 3931 0973 5595

HILLVIEW MOBILE COURT
P O Box 35944
CANTON, OH 44735

Re: STARK COUNTY
HILLVIEW MOBILE COURT
Community Water System
PWS ID: OH7602412
STU ID: 7658290
SMPID: EP001

Arsenic Maximum Contaminant Level (MCL) Exceedance

Dear Public Water System Owner:

This letter is notification that HILLVIEW MOBILE COURT is in violation for exceeding the maximum contaminant level (MCL) standard for arsenic of .010 mg/L as established in the Ohio Administrative Code (OAC) section 3745-81-11. Compliance with the arsenic MCL is based on a running annual average. The annual average for arsenic for the April 1 to June 30, 2007 time period is 0.091 mg/L.

To address the MCL violation the HILLVIEW MOBILE COURT is required to take the following actions:

- 1) ISSUE PUBLIC NOTICE:
Within thirty days, issue public notice according to the enclosed instructions. Complete and return the verification form along with a copy of the public notice to my attention at the letterhead address within ten days after it is issued. If arsenic levels continue to exceed the MCL, the public notification must be updated and repeated for each period that the arsenic MCL is exceeded. A verification form and copy of the public notice must be sent to Ohio EPA each time the notice is repeated. The enclosed draft public notice may be used verbatim. The mandatory health language for arsenic must appear in the public notice. If you wish to make any changes to this draft, telephone this office for verbal authorization prior to issuing the public notice.
- 2) CONTINUE TO SAMPLE FOR ARSENIC:
Continue collecting one sample for arsenic analysis on a quarterly basis. Your next sample should be collected between July 1 to October 31, 2007.
- 3) WORK TO RESOLVE THE PROBLEM:
Consult with your Ohio EPA district representative to discuss your options for coming into compliance and to establish a compliance schedule.

HILLVIEW MOBILE COURT
8/27/2007
Page Two

If you have questions regarding this correspondence, compliance with the arsenic standard, or questions regarding the public notice requirement, please contact me at (614) 644-2752.

Sincerely,

Kathleen Pinto

Kathleen Pinto
Compliance Assurance Section
Division of Drinking and Ground Waters

Enclosure: Public Notice and Instructions, Verification Form

cc: Superintendent/Manager; NEDO; DDAGW; Todd Kelleher, Supervisor, CU;
STARK County Health Dept.

DRINKING WATER NOTICE

Hillview Mobile Court Public Water System Has Levels of Arsenic Above Drinking Water Standards

Our water system has violated the maximum contaminant level (MCL) for Arsenic. The MCL for arsenic is based on an annual average level of arsenic collected over 4 quarters. The MCL for arsenic is 10 µg/L. At this time, the annual average arsenic level at Hillview Mobile Court is 91 µg/L.

What should I do?

We are ordered by the Stark County Health Department to provide you with an alternative (e.g., bottled) water. If you have specific health concerns, consult your doctor.

What does this mean?

Some people who drink water containing arsenic in excess of the MCL over many years could experience skin damage or problems with their circulatory system, and may have an increased risk of getting cancer.

What is being done?

We are required to investigate and take the necessary steps to correct the problem as soon as possible.

For more information, please contact _____ at _____ or _____
name of contact phone number mailing address

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

PWSID#: 7602412 _____ STUID#: 7658290 _____ Date distributed: _____

