



STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 644-2752 FAX:
www.epa.state.



NOTICE OF VIOLATION – ACTION REQUIRED

November 20, 2008

CERTIFIED MAIL

Hillview Mobile Court
Mr. William Walker
Po BOX 192
Massillon, OH 44646

Stark County
Hillview Mobile Court
Public Community PWS
PWS ID: OH7602412
Facility ID: 7658290

Subject: Violation of Maximum Contaminant Level for ARSENIC

Hillview Mobile Court is in violation for exceeding the maximum contaminant level (MCL) standard of 0.010 MG/L as established in the Ohio Administrative Code (OAC) section 3745-81-11 for ARSENIC. Compliance with the MCL is based on a running annual average. The annual average for ARSENIC during the Third Quarter of 2008 time period is 0.031 MG/L.

To address the MCL violation, Hillview Mobile Court is required to take the following actions:

- Notify your customers within 30 days using the enclosed instructions and public notice.
- Complete and send a verification form with a copy of the public notice to the above mailing address within ten days after issuance.
- Perform quarterly monitoring for ARSENIC during each calendar quarter (January 1 – March 31; April 1 – June 30; July 1 – September 30; October 1 to December 31).
- Consult with your Ohio EPA district representative to discuss your options for coming into compliance and establishing a compliance schedule or comply with any existing enforcement action that has been issued to you.

Your prompt attention to this matter is greatly appreciated. Continued noncompliance may lead to enforcement actions. If you have any questions or wish to change the public notice, please call me at (614) 644-2752.

Sincerely,

Kathleen Pinto
Division of Drinking and Ground Waters

Enclosure: Public Notice, Verification Form

cc: Northeast District Manager
Stark County Health Dept.

*also sent to PO Box 1214
Massillon OH 44648*
Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korfeski, Director

DRINKING WATER NOTICE

Hillview Mobile Court Has Levels of ARSENIC Above Drinking Water Standards

Our water system recently violated the maximum contaminant level (MCL) for ARSENIC during the 3rd quarter of 2008. The average level of ARSENIC over the last four quarters was 0.031 MG/L. The standard for ARSENIC is 0.010 MG/L.

What should I do?

- Hillview Mobile Court has agreed to provide bottled water for drinking and cooking purposes. If you have specific health concerns, consult your doctor.

What does this mean?

The levels detected do not pose an immediate risk to your health. However, some people who drink water containing ARSENIC in excess of the MCL over many years could experience skin damage or problems with their circulatory system, and may have an increased risk of getting cancer.

What is being done?

We are investigating obtaining water from the Village of Brewster, or installing treatment. Bottled water for drinking and cooking will be provided in the interim.

Additional information may be obtained by contacting:

Contact Person: _____

Phone Number: _____

Mailing Address: _____

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

PWSID: OH7602412 Facility ID: 7658290 Date Distributed: _____