



State of Ohio Environmen

OH7602412

HILLVIEW MOBILE COURT

1005

02 03/17/09

STREET ADDRESS:

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

TELE: (614) 644-2752 F.  
www.epa.state



**NOTICE OF VIOLATION – ACTION REQUIRED**

March 17, 2009

CERTIFIED MAIL

Hillview Mobile Court  
William E. Walker, Jr.  
P.O. BOX 192  
Massillon, OH 44648-0192

Stark County  
Hillview Mobile Court  
Public Community PWS  
PWS ID: OH7602412  
Facility ID: 7658290

**Subject: Violation of Maximum Contaminant Level for ARSENIC**

Hillview Mobile Court is in violation for exceeding the maximum contaminant level (MCL) standard of 0.010 MG/L as established in the Ohio Administrative Code (OAC) section 3745-81-11 for ARSENIC. Compliance with the MCL is based on a running annual average. The annual average for ARSENIC during the Fourth Quarter of 2008 time period is 0.03 MG/L.

To address the MCL violation, Hillview Mobile Court is required to take the following actions:

- Notify your customers within 30 days using the enclosed instructions and public notice.
- Complete and send a verification form with a copy of the public notice to the above mailing address within ten days after issuance.
- Perform quarterly monitoring for ARSENIC during each calendar quarter (January 1 – March 31; April 1 – June 30; July 1 – September 30; October 1 to December 31).
- Consult with your Ohio EPA district representative to discuss your options for coming into compliance and establishing a compliance schedule or comply with any existing enforcement action that has been issued to you.

Your prompt attention to this matter is greatly appreciated. Continued noncompliance may lead to enforcement actions. If you have any questions or wish to change the public notice, please call me at (614) 644-2752.


Sincerely,

Kathleen Pinto  
Division of Drinking and Ground Waters

Enclosure: Public Notice, Verification Form

cc: Northeast District Manager, N. Kathryn Walker, Stark Co. Health Dept.

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director



## DRINKING WATER NOTICE

### Levels of ARSENIC above Drinking Water Standards, and Monitoring Requirements Not Met for Hillview Mobile Court PWS.

The standard for ARSENIC is 10 µg/L.

Hillview Mobile Court's drinking water exceeded the arsenic maximum contaminant level (MCL) during the following time periods:

<u>Time Periods</u>	<u>Arsenic Running Annual Average</u>
July - September 2006	93 µg/L
October - December 2006	91 µg/L
January - March 2007	91 µg/L
April - June 2007	91 µg/L
July - September 2007	92 µg/L

<u>Time Periods</u>	<u>Arsenic Running Annual Average</u>
October - December 2007	72 µg/L
January - March 2008	56 µg/L
April - June 2008	42 µg/L
July - September 2008	31 µg/L
October - December 2008	30 µg/L

Additionally we are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During the listed periods we did not monitor for the following contaminants and therefore cannot be sure of the quality of our drinking water during that time.

<u>Contaminants</u>	<u>Time Periods</u>
Lead & Copper	June - September 2007
TTHM & HAA5	July - September 2007; October - December 2007; July - September 2008
Radionuclides	June - October 2007
Total Coliform	February 2008, July 2008

#### What should I do?

Hillview Mobile Court's previous notice regarding bottled water, which was posted at the mail boxes, was not accurate. We have installed arsenic treatment without Ohio EPA approval and the most recent arsenic results indicate that the arsenic levels in Hillview's water continue to exceed the health standard. **Therefore, Ohio EPA strongly recommends that you use bottled water for all drinking, food preparation, and oral hygiene until the Hillview Mobile Court connects to the Village of Brewster's water system. If you have specific health concerns, consult your doctor.**

#### What does this mean?

Some people who drink water containing ARSENIC in excess of the MCL over many years could experience skin damage or problems with their circulatory system, and may have an increased risk of getting cancer.

#### What is being done?

We are investigating obtaining water from the Village of Brewster. In the interim Ohio EPA is requiring that bottled water be provided to residents for all drinking, food preparation, and oral hygiene. We are required to make available at least five gallons of bottled water, per day, for each resident of Hillview Mobile Court. **The required bottled water is available in the small green barn, which is located just east of the common parking area, near the office.**

Also upon being notified of the monitoring violations, the water supplier was required to have the drinking water analyzed for the above mentioned parameters. The water supplier will take steps to ensure that adequate monitoring will be performed in the future.

For more information, please contact \_\_\_\_\_ at \_\_\_\_\_ or \_\_\_\_\_  
Name of contact phone number mailing address

*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.*

PWSID#: OH7602412 STUID#: 7658290 Date distributed: \_\_\_\_\_

## Attention All Hillview Mobile Court Residents

### **Hillview Mobile Court's Public Water System Has Levels of ARSENIC Above Drinking Water Standards.**

Please See Attached Drinking Water Public Notice, and Note the following:

- Hillview Mobile Court's most recent arsenic results indicate that the arsenic levels in Hillview's water continue to exceed the health standard. **Therefore, Ohio EPA strongly recommends that you use bottled water for all drinking, food preparation, and oral hygiene until the Hillview Mobile Court connects to the Village of Brewster's water system. If you have specific health concerns, consult your doctor.**
- We are required to make available at least five gallons of bottled water, per day, at our cost, for each resident of Hillview Mobile Court. **The required bottled water is available in the small green barn, which is located just east of the common parking area, near the office.**