



State of Ohio Environrr

OH7602412

HILLVIEW MOBILE COURT

1005

02 05/06/09

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 644-3021
www.epa.



NOTICE OF VIOLATION – ACTION REQUIRED

May 11, 2009

N. Kathryn Walker
Hillview Mobile Court
P. O. Box 1214,
Massillon, OH 44648-1214

Stark County
~~Hillview Mobile Court~~
Community PWS
PWS ID: OH7602412
Facility ID: 7658290

Subject: Violation of Maximum Contaminant Level for ARSENIC and Failure to Sample Drinking Water for TOTAL COLIFORMS, TOTAL TRIHALOMETHANES (TTHM), and HALOACETIC ACIDS FIVE (HAA5) as required.

Hillview Mobile Court is in violation for **exceeding the maximum contaminant level (MCL) standard of 0.010 mg/L** as established in the Ohio Administrative Code (OAC) section 3745-81-11 for ARSENIC. Compliance with the MCL is based on a running annual average. **The annual average for ARSENIC during the first quarter of 2009 time period is 0.0370 mg/L.**

Hillview Mobile Court is in violation of OAC, section 3745-81-21 for failure to comply with the total coliform monitoring.

Monitoring Period:	March 2009
Required Total Coliform Monitoring:	1 per Month
Sample Results Submitted:	0

To ensure the safety of drinking water provided by your system, monitoring for total coliform is essential. Your prompt attention to this matter is greatly appreciated.

Hillview Mobile Court is in violation of OAC, section 3745-81-24 for failure to comply with the TTHM and HAA5 monitoring.

Monitoring Period:	January 1 – March 31, 2009
Required TTHM Monitoring:	1 per Monitoring Quarter
Required HAA5 Monitoring:	1 per Monitoring Quarter
Sample Results Submitted:	0

If total coliform, TTHM or HAA5 samples were collected as required, submit the results as soon as possible, and the monitoring violations will be rescinded and a reporting violations will be given for the late submittal of the results.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director



To address the arsenic MCL violation and the total coliform, TTHM, and HAA5 monitoring violations, Hillview Mobile Court is required to take the following actions:

1. Immediately replace the Public Notice (PN) currently posted on the communal mailbox at Hillview, with a copy of the attached PN. The copy of the PN must be securely fastened, continually posted, and immediately replaced as necessary, as periodically revised by the Ohio EPA but without other revision, to the communal mailbox at Hillview, until Hillview Mobile Court is connected to the Village of Brewster's Public Water System.
2. Immediately distribute copies of the attached PN directly to each individual Hillview residence, and re-distribute to each individual Hillview residence on the 15th of each subsequent month, as periodically revised by the Ohio EPA but without other revision, until Hillview Mobile Court is connected to the Village of Brewster's Public Water System.
3. Complete and send the attached verification form, with a copy of each PN posted and/or distributed, to the above mailing address, within ten days after posting and distributing each PN.
4. Refrain from posting, delivering, or in any manner making available any other notice of any kind regarding the water that is available to the residents of Hillview, whether bottled or tap.
5. Perform quarterly monitoring for ARSENIC during each calendar quarter (January 1 – March 31; April 1 – June 30; July 1 – September 30; October 1 to December 31).
6. Perform quarterly monitoring for TTHM & HAA5 during each calendar quarter (January 1 – March 31; April 1 – June 30; July 1 – September 30; October 1 to December 31).
7. Perform monthly monitoring for TOTAL COLIFORM.

If you have any questions or wish to change the public notice, please call me at (614) 644-2752.

Sincerely,



Kathleen Pinto
Division of Drinking and Ground Waters

Enclosure: Laboratory List, Public Notice, Verification Form

cc: Stark County Health Dept., Manager; NEDO

Attention All Hillview Mobile Court Residents

Hillview Mobile Court's Public Water System Has Levels of ARSENIC Above Drinking Water Standards.

Please See Attached Drinking Water Public Notice, and Note the following:

- Hillview Mobile Court's most recent arsenic results indicate that the arsenic levels in Hillview's water continue to exceed the health standard. **Therefore, Ohio EPA strongly recommends that you use bottled water for all drinking, food preparation, and oral hygiene until the Hillview Mobile Court connects to the Village of Brewster's water system. If you have specific health concerns, consult your doctor.**
- We are required to make available at least five gallons of bottled water, per day, at our cost, for each resident of Hillview Mobile Court. **The required bottled water is available in the small green barn, which is located just east of the common parking area, near the office.**

DRINKING WATER NOTICE

Levels of ARSENIC above Drinking Water Standards, and Monitoring Requirements Not Met for Hillview Mobile Court PWS.

The standard for ARSENIC is 10 µg/L.

Hillview Mobile Court's drinking water exceeded the arsenic maximum contaminant level (MCL) during the following time periods:

<u>Time Period</u>	<u>Arsenic Running Annual Average</u>
January - March 2009	37 µg/L

Additionally we are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During the listed periods we did not monitor for the following contaminants and therefore cannot be sure of the quality of our drinking water during that time.

<u>Contaminants</u>	<u>Time Periods</u>
Total Coliform	March 2009
TTHM & HAA5	January - March 2009

What should I do?

The most recent arsenic result indicates that the arsenic levels in Hillview's water continue to exceed the health standard. Therefore, Ohio EPA strongly recommends that you use bottled water for all drinking, food preparation, and oral hygiene until the Hillview Mobile Court connects to the Village of Brewster's water system. If you have specific health concerns, consult your doctor.

What does this mean?

Some people who drink water containing ARSENIC in excess of the MCL over many years could experience skin damage or problems with their circulatory system, and may have an increased risk of getting cancer.

What is being done?

We are investigating obtaining water from the Village of Brewster. In the interim Ohio EPA is requiring that bottled water be provided to residents for all drinking, food preparation, and oral hygiene. We are required to make available at least five gallons of bottled water, per day, for each resident of Hillview Mobile Court. **The required bottled water is available in the small green barn, which is located just east of the common parking area, near the office.**

Also upon being notified of the monitoring violations, the water supplier was required to have the drinking water analyzed for the above mentioned parameters. The water supplier will take steps to ensure that adequate monitoring will be performed in the future.

For more information, please contact _____ at _____ or _____.
Name of contact phone number mailing address

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

PWSID#: OH7602412 STUID#: 7658290 Date distributed: _____

**PUBLIC NOTICE INSTRUCTIONS AND VERIFICATION FORM FOR
HILLVIEW MOBILE COURT VIOLATIONS**

I HEREBY CERTIFY THAT THE PUBLIC WAS NOTIFIED BY THE FOLLOWING METHOD(S) INDICATED BELOW:

Required Method of Public Notification	Actual Method of Public Notification
<p>Use the following methods to reach all persons served by the public water system:</p> <p>1. Must issue public notice (PN) by mail or other direct delivery to each customer and service connection (where known). The PN must be re-distributed to each individual Hillview residence on the 15th of each subsequent month, as periodically revised by the Ohio EPA but without other revision, until Hillview Mobile Court is connected to the Village of Brewster's Public Water System.</p> <p>2. Securely fasten, continually post, and immediately replace as necessary, as periodically revised by the Ohio EPA but without other revision, to the communal mailbox at Hillview Mobile Court, until Hillview Mobile Court is connected to the Village of Brewster's Public Water System.</p>	<p>Describe actual methods used to notify public of the violation:</p> <p>1. Dates of mailing/delivery _____</p> <p>2. Date of posting _____</p>
<p>If the above methods do not reach all persons served, also use any other method reasonably calculated to reach other persons served by the system (e.g. publication in a local newspaper or newsletter, use of e-mail to notify employees or students, or delivery of multiple copies to central locations).</p>	<p>A. Method(s) _____ _____ _____</p> <p>B. Date(s) _____</p>

Please check if the public notice used was provided by Ohio EPA (other side of this form) or another acceptable notice was used:

- A public notice as shown on the other side of this sheet was issued without changes.
- A different public notice was issued. **INCLUDE A COPY OF THE PUBLIC NOTICE.**

 Signature of Responsible Person Date

PWS NAME: Hillview Mobile Court
 PWSID: OH7602412 Facility ID: 7658290
 COUNTY: Stark

 Printed Name and Title of Responsible Person

<u>CONTAMINANT</u>	<u>MONITORING PERIOD</u>
Arsenic MCL	Jan-March 09
Total Coliform M/R	March 09
TTHM & HAA5 M/R	Jan-March 09

<p><u>For Ohio EPA use only:</u> Date PN received: _____ PN acceptable: _____ PN not acceptable: _____</p>
--

