



State of Ohio Environme

OH7602412

HILLVIEW MOBILE COURT

1005

02 11/24/09

STREET ADDRESS:

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

TELE: (614) 644-3020  
www.epa.st



**NOTICE OF VIOLATION – ACTION REQUIRED**

November 24, 2009

CERTIFIED MAIL

William E. Walker, Jr.  
Hillview Mobile Court  
P. O. Box 192,  
Massillon, OH 44648-0192

Stark County  
Hillview Mobile Court  
Community PWS  
PWS ID: OH7602412  
Facility ID: 7658290

**Subject: Violation of Maximum Contaminant Level for ARSENIC and Failure to Sample Drinking Water for TOTAL COLIFORMS as required.**

Hillview Mobile Court is in violation for **exceeding the maximum contaminant level (MCL) standard of 0.010 mg/L** as established in the Ohio Administrative Code (OAC) section 3745-81-11 for ARSENIC. Compliance with the MCL is based on a running annual average. **The annual average for ARSENIC during the third quarter of 2009 time period is 0.065 mg/L.**

**Hillview Mobile Court is in violation of OAC, section 3745-81-21 for failure to comply with the total coliform monitoring.**

<b>Monitoring Period:</b>	October 2009
<b>Required Total Coliform Monitoring:</b>	1 per Month
<b>Sample Results Submitted:</b>	0

To ensure the safety of drinking water provided by your system, monitoring for total coliform is essential. Your prompt attention to this matter is greatly appreciated.

If total coliform samples were collected as required, submit the results as soon as possible; and the monitoring violation will be rescinded and a reporting violation will be given for the late submittal of the results.

**To address the arsenic MCL violation and the total coliform monitoring violation, Hillview Mobile Court is required to take the following actions:**

1. Immediately replace the Public Notice (PN) currently posted on the communal mailbox at Hillview, with a copy of the attached PN (the PN must remain posted for at least 7 days).
2. Immediately distribute copies of the attached PN directly to each individual Hillview residence without other revision.
3. Complete and send the attached verification form, with a copy of each PN posted and/or distributed, to the above mailing address, within ten days after posting and distributing each PN.

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director



If you have any questions or wish to change the public notice, please call me at (614) 644-2752.

Sincerely,

*Kathleen Pinto*

Kathleen Pinto  
Division of Drinking and Ground Waters

Enclosure: Public Notice, Verification Form

cc: Stark County Health Dept., Manager; NEDO

**DRINKING WATER NOTICE**  
**Levels of ARSENIC above Drinking Water Standards, and Monitoring Requirements**  
**Not Met for Hillview Mobile Court PWS.**

The standard for ARSENIC is 10 µg/L.

Hillview Mobile Court's drinking water exceeded the arsenic maximum contaminant level (MCL) during the following time periods:

<u>Time Period</u>	<u>Arsenic Running Annual Average</u>
July - September 2009	65 µg/L

*Additionally we are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During the listed periods we did not monitor for the following contaminants and therefore cannot be sure of the quality of our drinking water during that time.*

<u>Contaminants</u>	<u>Time Periods</u>
Total Coliform	October 2009

**What should I do?**

The most recent arsenic result indicates that the arsenic levels in Hillview's water exceeded the health standard. **If you have specific health concerns, consult your doctor.**

**What does this mean?**

Some people who drink water containing ARSENIC in excess of the MCL over many years could experience skin damage or problems with their circulatory system, and may have an increased risk of getting cancer.

**What is being done?**

**As of November 17, 2009, Hillview Mobile Court is now being supplied water from the Village of Brewster's Public Water System, as such Ohio EPA is no longer requiring that bottled water be provided to residents.**

For more information, please contact \_\_\_\_\_ at \_\_\_\_\_ or \_\_\_\_\_.  
Name of contact phone number mailing address

*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.*

PWSID#: OH7602412 STUID#: 7658290 Date distributed: \_\_\_\_\_

