

7006 2760 0003 0920 0780 7798

**U.S. Postal Service**  
**CERTIFIED MAIL RECEIPT**  
(Domestic Mail Only; No Insurance Coverage Provided)

For delivery information visit our website at [www.usps.com](http://www.usps.com)

**OFFICIAL USE**

Postage	\$
Certified Fee	
Return Receipt Fee (Endorsement Required)	
Restricted Delivery Fee (Endorsement Required)	
Total Postage & Fees	

FROM:  
LAURA POHLMAN  
- S.W. DIV.  
Postmark  
Here

Sent To	MAYOR AND COUNCIL
Street, Apt. No.; or PO Box No.	VILLAGE OF ANSONIA
City, State, ZIP+4	202 NORTH MAIN ST P O BOX 607 ANSONIA OH 45303

See Reverse for Instructions

## **Certified Mail Provides:**

- A mailing receipt
- A unique identifier for your mailpiece
- A record of delivery kept by the Postal Service for two years

### ***Important Reminders:***

- Certified Mail may ONLY be combined with First-Class Mail® or Priority Mail®.
- Certified Mail is *not* available for any class of International mail.
- NO INSURANCE COVERAGE IS PROVIDED with Certified Mail. For valuables, please consider Insured or Registered Mail.
- For an additional fee, a *Return Receipt* may be requested to provide proof of delivery. To obtain Return Receipt service, please complete and attach a Return Receipt (PS Form 3811) to the article and add applicable postage to cover the fee. Endorse mailpiece "Return Receipt Requested". To receive a fee waiver for a duplicate return receipt, a USPS® postmark on your Certified Mail receipt is required.
- For an additional fee, delivery may be restricted to the addressee or addressee's authorized agent. Advise the clerk or mark the mailpiece with the endorsement "*Restricted Delivery*".
- If a postmark on the Certified Mail receipt is desired, please present the article at the post office for postmarking. If a postmark on the Certified Mail receipt is not needed, detach and affix label with postage and mail.

**IMPORTANT: Save this receipt and present it when making an inquiry.**

PS Form 3800, August 2006 (Reverse) PSN 7530-02-000-9047



State of Ohio Environmental Protection Agency

Southwest District Office

401 East Fifth Street  
Dayton, Ohio 45402-2911

TELE: (937) 285-6357 FAX: (937) 285-6249  
[www.epa.state.oh.us](http://www.epa.state.oh.us)

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

July 5, 2007

Mayor and Council  
Village of Ansonia  
202 North Main Street  
P.O. Box 607  
Ansonia, Ohio 45303

**CERTIFIED MAIL**

**Re: Self-Monitoring Report NOV- June 2006 through May 2007  
Village of Ansonia WWTP, Darke County  
NPDES Permit No. 1PB00005\*JD/OH0023884**

Dear Mayor and Council:

We have reviewed your Monthly Operating Reports (MORs) covering the months from June 2006 through May 2007 for the referenced facility. Our review indicates violations of the conditions of your NPDES Permit (NPDES Permit # OH0023884; OEPA Permit # 1PB00005\*JD). The specific instances of noncompliance and/or deficiencies were as follows:

Effluent Limit Violations of Outfall 001				
Reporting Period	Parameter	Limit Type	Permit Limit	Reported Value
June 2006	pH	1D Conc	9.0	9.6
June 2006	pH	1D Conc	9.0	9.3
June 2006	pH	1D Conc	9.0	9.5
June 2006	pH	1D Conc	9.0	9.6
June 2006	pH	1D Conc	9.0	9.5
June 2006	pH	1D Conc	9.0	9.5
June 2006	pH	1D Conc	9.0	9.4
June 2006	pH	1D Conc	9.0	9.3
June 2006	pH	1D Conc	9.0	9.4
June 2006	pH	1D Conc	9.0	9.4
June 2006	pH	1D Conc	9.0	9.4
June 2006	pH	1D Conc	9.0	9.4
June 2006	pH	1D Conc	9.0	9.3
June 2006	pH	1D Conc	9.0	9.4
June 2006	pH	1D Conc	9.0	9.2



Effluent Limit Violations of Outfall 001- cont.

Reporting Period	Parameter	Limit Type	Permit Limit	Reported Value
June 2006	pH	1D Conc	9.0	9.2
June 2006	pH	1D Conc	9.0	9.5
June 2006	pH	1D Conc	9.0	9.4
June 2006	pH	1D Conc	9.0	9.4
June 2006	pH	1D Conc	9.0	9.3
July 2006	pH	1D Conc	9.0	9.5
July 2006	pH	1D Conc	9.0	9.4
July 2006	pH	1D Conc	9.0	9.5
July 2006	pH	1D Conc	9.0	9.4
July 2006	pH	1D Conc	9.0	9.4
July 2006	pH	1D Conc	9.0	9.4
July 2006	pH	1D Conc	9.0	9.3
July 2006	pH	1D Conc	9.0	9.1
July 2006	pH	1D Conc	9.0	9.3
July 2006	pH	1D Conc	9.0	9.3
July 2006	pH	1D Conc	9.0	9.2
July 2006	pH	1D Conc	9.0	9.2
July 2006	pH	1D Conc	9.0	9.3
July 2006	pH	1D Conc	9.0	9.3
July 2006	pH	1D Conc	9.0	9.1
July 2006	pH	1D Conc	9.0	9.3
August 2006	pH	1D Conc	9.0	9.3
August 2006	DO	1D Conc	5.0	4.4
August 2006	pH	1D Conc	9.0	9.2
August 2006	pH	1D Conc	9.0	9.3
August 2006	DO	1D Conc	5.0	4.8
August 2006	pH	1D Conc	9.0	9.3
August 2006	pH	1D Conc	9.0	9.3
August 2006	pH	1D Conc	9.0	9.3
August 2006	pH	1D Conc	9.0	9.4
August 2006	pH	1D Conc	9.0	9.2
August 2006	pH	1D Conc	9.0	9.4
August 2006	pH	1D Conc	9.0	9.4
August 2006	pH	1D Conc	9.0	9.3
August 2006	pH	1D Conc	9.0	9.4
August 2006	pH	1D Conc	9.0	9.3
August 2006	pH	1D Conc	9.0	9.4
August 2006	pH	1D Conc	9.0	9.3



Effluent Limit Violations of Outfall 001-cont.

Reporting Period	Parameter	Limit Type	Permit Limit	Reported Value
November 2006	pH	1D Conc	9.0	9.2
November 2006	pH	1D Conc	9.0	9.1
November 2006	pH	1D Conc	9.0	9.1
November 2006	pH	1D Conc	9.0	9.1
November 2006	pH	1D Conc	9.0	9.1
November 2006	pH	1D Conc	9.0	9.1
November 2006	pH	1D Conc	9.0	9.1
November 2006	pH	1D Conc	9.0	9.2
November 2006	pH	1D Conc	9.0	9.1
November 2006	pH	1D Conc	9.0	9.1
December 2006	pH	1D Conc	9.0	9.3
December 2006	pH	1D Conc	9.0	9.1
December 2006	pH	1D Conc	9.0	9.4
December 2006	pH	1D Conc	9.0	9.1
December 2006	pH	1D Conc	9.0	9.3
December 2006	pH	1D Conc	9.0	9.4
December 2006	pH	1D Conc	9.0	9.1
December 2006	pH	1D Conc	9.0	9.2
December 2006	pH	1D Conc	9.0	9.3
December 2006	pH	1D Conc	9.0	9.1
December 2006	pH	1D Conc	9.0	9.1
December 2006	pH	1D Conc	9.0	9.1
December 2006	pH	1D Conc	9.0	9.2
December 2006	pH	1D Conc	9.0	9.2
December 2006	pH	1D Conc	9.0	9.1
December 2006	pH	1D Conc	9.0	9.1
December 2006	pH	1D Conc	9.0	9.1
December 2006	pH	1D Conc	9.0	9.1
December 2006	pH	1D Conc	9.0	9.1
January 2007	pH	1D Conc	9.0	9.1
January 2007	pH	1D Conc	9.0	9.1
January 2007	pH	1D Conc	9.0	9.2
January 2007	pH	1D Conc	9.0	9.1
January 2007	pH	1D Conc	9.0	9.2
January 2007	pH	1D Conc	9.0	9.1
January 2007	pH	1D Conc	9.0	9.1
January 2007	pH	1D Conc	9.0	9.1
January 2007	pH	1D Conc	9.0	9.1

Effluent Limit Violations of Outfall 001-cont.				
Reporting Period	Parameter	Limit Type	Permit Limit	Reported Value
January 2007	pH	1D Conc	9.0	9.2
January 2007	pH	1D Conc	9.0	9.2
January 2007	pH	1D Conc	9.0	9.1
January 2007	pH	1D Conc	9.0	9.2
January 2007	pH	1D Conc	9.0	9.2
January 2007	pH	1D Conc	9.0	9.2
January 2007	pH	1D Conc	9.0	9.1
January 2007	pH	1D Conc	9.0	9.1
January 2007	pH	1D Conc	9.0	9.1
January 2007	pH	1D Conc	9.0	9.2
February 2007	pH	1D Conc	9.0	9.2
February 2007	pH	1D Conc	9.0	9.2
February 2007	pH	1D Conc	9.0	9.2
February 2007	pH	1D Conc	9.0	9.1
February 2007	pH	1D Conc	9.0	9.3
February 2007	pH	1D Conc	9.0	9.1
February 2007	pH	1D Conc	9.0	9.1
March 2007	CBOD 5	30D Qty	33.1	37.9
March 2007	Ammonia	7D Qty	7.0	11.5
March 2007	Ammonia	30D Conc	3.5	4.4
March 2007	Ammonia	30D Qty	4.6	20.8
March 2007	DO	1D Conc	5.0	4.8
March 2007	Ammonia	7D Qty	7.0	24.9
March 2007	Ammonia	7D Qty	7.0	24
March 2007	CBOD 5	7D Qty	53.0	63.8
March 2007	Ammonia	7D Qty	7.0	18.3
March 2007	TSS	7D Qty	119	139.4
April 2007	pH	1D Conc	9.0	9.1
April 2007	pH	1D Conc	9.0	9.1
April 2007	pH	1D Conc	9.0	9.1
May 2007	pH	1D Conc	9.0	9.4
May 2007	pH	1D Conc	9.0	9.3
May 2007	pH	1D Conc	9.0	9.3
May 2007	pH	1D Conc	9.0	9.3
May 2007	pH	1D Conc	9.0	9.1
May 2007	pH	1D Conc	9.0	9.2

Effluent Limit Violations of Outfall 001-cont.				
Reporting Period	Parameter	Limit Type	Permit Limit	Reported Value
May 2007	pH	1D Conc	9.0	9.3
May 2007	pH	1D Conc	9.0	9.3
May 2007	pH	1D Conc	9.0	9.2
May 2007	pH	1D Conc	9.0	9.4
May 2007	pH	1D Conc	9.0	9.1
May 2007	pH	1D Conc	9.0	9.2
May 2007	pH	1D Conc	9.0	9.1
May 2007	pH	1D Conc	9.0	9.3

Frequency Violations for Outfall 001						
Reporting Period	Violation Date	Station	Parameter	Sample Frequency	Expected	Reported
November 2006	11/22/2006	001	TSS	2/Week	2	1
November 2006	11/22/2006	001	Ammonia	2/Week	2	1
November 2006	11/22/2006	001	CBOD5	2/Week	2	1
January 2007	1/1/2007	001	Total Precipitation	1/Month	1	0

Frequency Violations for Outfall 601						
Reporting Period	Violation Date	Station	Parameter	Sample Frequency	Expected	Reported
November 2006	11/22/2006	601	TSS	2/Week	2	1
November 2006	11/22/2006	601	CBOD5	2/Week	2	1
April 2007	4/22/2007	601	TSS	2/Week	2	1
April 2007	4/22/2007	601	CBOD5	2/Week	2	1
May 2007	5/22/2007	601	CBOD5	2/Week	2	1

33  
Mayor and Council  
July 5, 2007  
Page 7

Frequency Violations for Outfall 602						
Reporting Period	Violation Date	Station	Parameter	Sample Frequency	Expected	Reported
March 2007	3/8/2007	602	CBOD 5 day	2/Week	2	1
May 2007	5/1/2007	602	pH	2/Week	2	1
May 2007	5/1/2007	602	Flow Rate	2/Week	2	0
May 2007	5/8/2007	602	Flow Rate	2/Week	2	0
May 2007	5/15/2007	602	Flow Rate	2/Week	2	0
May 2007	5/22/2007	602	Flow Rate	2/Week	2	0


Frequency Violation for Outfall 801						
Reporting Period	Violation Date	Station	Parameter	Sample Frequency	Expected	Reported
July 2006	7/1/2006	801	Water Temperature	1/Month	1	0

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Please inform this office, in writing, within ten days of receipt of this notification as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions. Future violations must be reported as required by the NPDES Permit as detailed in Part III.12 titled "Noncompliance Notification."

If you have any questions regarding the above, please contact me at (937) 285-9749.

Sincerely,



Laura Pohlman  
Division of Surface Water  
Permit Section

cc: Darke County Health Department

