



State of Ohio Environmental Protection Agency

Southwest District Office

401 E. Fifth St.  
Dayton, Ohio 45402

TELE: (937) 285-6357 FAX: (937) 285-6249  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

February 6, 2007

~~Franklin Monroe Elementary School~~

Attn: David Gray, Superintendent  
8639 Oakes Road  
P.O. Box 78  
Pittsburg, OH 45358

**RE: NOTICE OF VIOLATION – Franklin Monroe Elementary School, Darke County  
NPDES Permit No. 1PT00115\*AD/OH0133949**

Dear Mr. Gray,

We have reviewed your self-monitoring reports for the period of June 2006 to December 2006 for the above referenced facility. Our review indicates violations of the conditions of your NPDES Permit. The specific instances of noncompliance and deficiencies are as follows:

Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
31616	Fecal Coliform	30D Conc	1000	7600	9/1/2006
31616	Fecal Coliform	7D Conc	2000	7600	9/15/2006
80082	CBOD 5 day	30D Conc	25.0	38	10/1/2006
00300	Dissolved Oxygen	1D Conc	5.0	4.8	10/10/2006
00530	Total Suspended Solids	30D Conc	12	24	11/1/2006
00610	Nitrogen, Ammonia (NH3)	30D Conc	3.0	19.6	11/1/2006
80082	CBOD 5 day	30D Conc	10	97	11/1/2006
00530	Total Suspended Solids	7D Conc	18	24	11/15/2006
00610	Nitrogen, Ammonia (NH3)	7D Conc	4.5	19.6	11/15/2006
80082	CBOD 5 day	7D Conc	15	97	11/15/2006
00300	Dissolved Oxygen	1D Conc	6.0	3.1	11/21/2006
00530	Total Suspended Solids	30D Conc	12	44	12/1/2006
00610	Nitrogen, Ammonia (NH3)	30D Conc	3.0	48.4	12/1/2006
80082	CBOD 5 day	30D Conc	10	26	12/1/2006
00530	Total Suspended Solids	7D Conc	18	44	12/15/2006
00610	Nitrogen, Ammonia (NH3)	7D Conc	4.5	48.4	12/15/2006
80082	CBOD 5 day	7D Conc	15	26	12/15/2006
00300	Dissolved Oxygen	1D Conc	6.0	2.3	12/19/2006



Franklin Monroe Elementary School  
February 6, 2007  
Page 2

These violations were reported as required by the NPDES Permit by self notification. Your operator, Gary Wagner has provided letters detailing the violations and the cause of the violations.

As you know, the Schedule of Compliance in your NPDES permit required completion of construction for wastewater system improvements by July 1, 2006. This requirement has not been met. Failure to meet the Schedule of Compliance dates is grounds for enforcement action by Ohio EPA.

Your previous correspondence explained that the elementary school is planned to be eliminated and combined into a new K-12 building. As I understand from conversation with Gary Wagner, funding from the Ohio School Facilities Commission has been earmarked for the Franklin Monroe School District. Provide an update on the proposed location of the new K-12 building, funding, and construction schedule. Also, describe the actions being taken to reduce the aforementioned violations at the current elementary school location. Provide your response by **March 6, 2007**. Should you have any questions, I can be contacted at (937) 285-6109.

Sincerely,



Joe Miller  
Division of Surface Water  
Compliance and Enforcement

CC: Gary Wagner, Operator  
Jill Beiser, FMES  
Darke County Health Department

