



**Environmental  
Protection Agency**

Ted Strickland, Governor  
Lee Fisher, Lt. Governor  
Chris Korleski, Director



\*1PR0011220110725\*

DARKE

GREENVILLE COUNTRY CLUB

MILLER, JOSEPH

2011/07/25



**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

July 27, 2011

Greenville Country Club  
6545 State Route 36  
P.O. Box 36  
Greenville, OH 45331

**RE: NOTICE OF VIOLATION  
Reconnaissance Inspection (RI)  
Greenville Country Club Wastewater  
NPDES Permit 1PR00112\*BD/OH0131881  
Darke County**

Ladies and Gentlemen:

On June 28, 2011, I conducted a Reconnaissance Inspection at the Greenville Country Club wastewater treatment plant. This inspection was conducted to determine compliance with the NPDES discharge permit. The wastewater treatment plant discharges to an unnamed tributary of Greenville Creek. Greenville Creek is a State Scenic River.

I have reviewed your monitoring reports for the period covering January 2010 to June 2011. This review indicates violations of the conditions of your NPDES permit. The specific instances of non-compliance are listed below:

**Greenville Country Club WWTP Effluent Limit Violations January 2010 to June 2011**

Reporting Period	Parameter	Limit Type	Limit	Reported Value	Violation Date
March 2010	pH	1D Conc	6.5	6.3	3/1/2010
March 2010	pH	1D Conc	6.5	6.3	3/2/2010
March 2010	pH	1D Conc	6.5	6.3	3/3/2010
March 2010	pH	1D Conc	6.5	6.3	3/4/2010
March 2010	pH	1D Conc	6.5	6.3	3/5/2010
June 2010	Dissolved Oxygen	1D Conc	6.0	5.5	6/14/2010
June 2010	Dissolved Oxygen	1D Conc	6.0	5.5	6/15/2010
June 2010	Dissolved Oxygen	1D Conc	6.0	5.5	6/16/2010
June 2010	Dissolved Oxygen	1D Conc	6.0	5.5	6/17/2010
June 2010	Dissolved Oxygen	1D Conc	6.0	5.5	6/18/2010

**Non-compliance notification is required for all violations as detailed in the NPDES permit, Part III, Item 12. Any future incidences must be reported in this manner.**

At the time of inspection, the wastewater treatment plant appeared to be operating and the effluent appeared clear.

Steve Crawford, WW3, provided notification of becoming the operator of record for the Greenville Country Club on November 29, 2010.

A response is requested for the following items:

**Effluent Violations** – Detail the reasons for the listed violations. Your response should include dates, either actual or proposed, for completion of actions to prevent future violations. Please note the requirement to provide Non-Compliance Notification.

Provide this office a written response by **August 22, 2011**, to the above item. If you have any questions, I can be reached at (937) 285-6109.

Sincerely,



Joe Miller  
Division of Surface Water


ec: Darke County Health Department  
Steve Crawford, Operator of Record



Figure 1. Greenville Country Club WWTP, JGM 6/28/11



Figure 2. Greenville Country Club WWTP sandfilters, JGM 6/28/11





State of Ohio Environmental Protection Agency  
Southwest District Office

NPDES Compliance Inspection Report

Section A: National Data System Coding					
Permit #	NPDES#	Month/Day/Year	Inspection Type	Inspector	Facility Type
1PR00112*BD	OH0131881	6/28/11	R	S	2

Section B: Facility Data		
<b>Name and Location of Facility Inspected</b> Greenville Country Club WWTP 6545 State Route 36 Greenville, OH 45331	<b>Entry Time</b> 11:15 AM	<b>Permit Effective Date</b> July 1, 2007
	<b>Exit Time</b> 11:30 AM	<b>Permit Expiration Date</b> June 30, 2012
<b>Name(s) and Title(s) of On-Site Representatives</b> N/A	<b>Phone Number(s)</b>	
<b>Name, Address and Title of Responsible Official</b> Greenville Country Club 6545 State Route 36 P.O. Box 36 Greenville, OH 45331	<b>Phone Number</b> 937-548-2700	

Section C: Areas Evaluated During Inspection					
(S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated)					
S	Permit	S	Flow Measurement	N	Pretreatment
S	Records/Reports	N	Laboratory	N	Compliance Schedule
S	Operations & Maintenance	S	Effluent/Receiving Waters	M	Self-Monitoring Program
S	Facility Site Review	S	Sludge Storage/Disposal	N	Other
N	Collection System				

Section D: Summary of Findings (Attach additional sheets if necessary)	
Self-Monitoring rated as Marginal due to failure to provided non-compliance notification as per the NPDES perm.	
<b>Inspector</b>  Joe Miller Division of Surface Water Southwest District Office	<b>Reviewer</b>  Martyn Burt Compliance & Enforcement Supervisor Division of Surface Water Southwest District Office
7-27-11 Date	7/27/11 Date

